

SEWER MAIN/SERVICE PROBLEMS

DATE: 9/26/85

TIME: 2.47 Pm

NAME: Class A. Rest.

ADDRESS: 168 No. Pleas. St.

COMPLAINT RECEIVED BY: ~~Sever~~ AN

PROBLEM: Sewer

COMPLAINT REFERRED TO: Fred FOR ACTION

DATE: 9/26/85

TIME: 2.45 Pm

ACTION TAKEN: Sewer main plugged from manhole on No Pleas  
to manhole on Calix Ln. Used flusher to unplug  
line O.K. & reset.

When flushing see a lot of wooden ice cream  
sticks come down line

If the problem is on Town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by the Public Works Department to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and/or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

Fred Fuller  
Foreman/Employee in Charge (Signature)

Date: 9/26/85

SEWER MAIN/SERVICE PROBLEMS

DATE: 4/1/81

TIME: 2:30 PM

NAME: FRENCH + GUYOTTE

ADDRESS: GAS LITE TR - Cowles Lane<sup>168</sup> No. Pleasant

COMPLAINT RECEIVED BY: HANIK

PROBLEM: SEWER PLUGGED UP

COMPLAINT REFERRED TO: John Westworth FOR ACTION

DATE: 4/1/81

TIME: 2:30

ACTION TAKEN: FLUSHED MAIN TWICE WITH JET  
NO PROBLEM - CALLED BACK FRENCH  
+ GUYOTTE

If the problem is on Town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by Public Works Department to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

John Westworth

Date: 4/1/81

Foreman/Employee in Charge (Signature)

SEWER MAIN/SERVICE PROBLEMS

DATE: Aug 13, 81

TIME: 7:15 AM

NAME: Gas Lite II

ADDRESS: 168 No. Pleasant St.

COMPLAINT RECEIVED BY: SPJ

PROBLEM: Sewer

COMPLAINT REFERRED TO: K. Jenks FOR ACTION

DATE: 8/13/81

TIME: 7:15 AM

ACTION TAKEN: Main sewer line on Court St. was cleared out which was running a little. However, had to flush line with hoses.

If the problem is on Town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by Public Works Department to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

K. Jenks

Date: 8/13/81

Foreman/Employee in Charge (Signature)

SEWER MAIN/SERVICE PROBLEMS

DATE: Oct 26, 81

TIME: 11.25 AM

NAME: Gas Lite #

ADDRESS: <sup>160</sup> 160 Pleasant St.

COMPLAINT RECEIVED BY: Hank

PROBLEM: Sewer

COMPLAINT REFERRED TO: R. Jenks FOR ACTION

DATE: 10/26/81

TIME: 11.30 AM

ACTION TAKEN: The town flushed out sewer main going up courts to make sure it was not the Town's Problem.

It proved to be owners Problem inside of Building (Basement)

If the problem is on Town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by Public Works Department to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

R. Jenks

Date: 10/26/81

Foreman/Employee in Charge (Signature)

SEWER MAIN/SERVICE PROBLEMS

DATE: 7-25-80

TIME: 7:35 PM

NAME: CASLITE II

ADDRESS: 168 NO PLEASANT

COMPLAINT RECEIVED BY: Police Dept

PROBLEM: SEWER BACKUP

COMPLAINT REFERRED TO: Charles Mosakiewicz FOR ACTION

DATE: 7-25-80

TIME: 7:20 PM

ACTION TAKEN: CHECK MANHOLES LINE OK  
PROBLEM 50 FT FROM BUILDING ON  
OWNER'S LINE

If the problem is on Town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by Public Works Department to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

Charles Mosakiewicz

Date: 7-25-80

Foreman/Employee in Charge (Signature)

SEWER MAIN/SERVICE PROBLEMS

DATE: 10/9/80

TIME: 2.30 Pm

NAME: Gas Lib #11 - Andy Bunch

ADDRESS: 168 No. Pleas. St.

COMPLAINT RECEIVED BY: Hank

PROBLEM: sewer problem

COMPLAINT REFERRED TO: R. Jenks FOR ACTION

DATE: 10/9/80

TIME: 2.35 Pm

ACTION TAKEN: Sewer was backing into Gas Lib #11  
Sewer line was freed w/ flusher

If the problem is on Town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by Public Works Department to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

Fred F. - Kay

Date: \_\_\_\_\_

Foreman/Employee in Charge (Signature)

SEWER MAIN/SERVICE PROBLEMS

DATE: Oct 27, 80

TIME: 7.55 A.M.

NAME: Yao Litz TT

ADDRESS: <sup>100</sup>100 Pleasant St.

COMPLAINT RECEIVED BY: \_\_\_\_\_

PROBLEM: Sewer

COMPLAINT REFERRED TO: Ken J. FOR ACTION

DATE: 10/27/80

TIME: 8.00 A.M.

ACTION TAKEN: Sewer line on courts home was running  
However line was flushed out with flushes.

If the problem is on Town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by Public Works Department to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

K. Jenks

Date: Oct 27, 80

Foreman/Employee in Charge (Signature)

SEWER MAIN/SERVICE PROBLEMS

Date: 10/9/78

Time: 2.00 Pm

Name: Max Litz #

Address: 168 No. Pleasant

Complaint Received By: PD

Problem: Sewer Problem

Complaint Referred to: Fred for action.

Date: 10/9/78 Time: 2.15 Pm

Action taken: Run Rods in sewer main from North Plea up Cowls Lane. Unplugged main OK now

If the problem is on town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by the Public works Dept. to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

Fred Fuller  
Foreman/Employee in Charge (Signature)

Date: 10/9/78

SEWER MAIN/SERVICED PROBLEMS

Date: 12/7/78

Time: 10.52 AM

Name: Gas Lite # - Kathy

Address: <sup>108</sup> No. Pleasant St.

Complaint Received By: Hank

Problem: Sewer problem

Complaint Referred to: Ken Jenks for action.

Date: 12/7/78 Time: 11.55 AM

Action taken: Main line was plugged  
Town ~~was~~ rodded out main line and  
owner was notified

If the problem is on town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by the Public Works Dept. to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or tenant so they can be aware of the situation.

All reports shall be turned into the office on a daily basis.

Foreman/Employee in Charge (Signature) \_\_\_\_\_ Date: 12/7/78

SEWER MAIN/SERVICE PROBLEMS

Date: 10-23-76 Time: 10:30 AM

Name: 168 W. Pearson  
Jean Hussey / Gas lite II

Address: Jubist st, Belknapton MA. 323-6934

Complaint Received By: APD/Jeff

Problem: Sewer Back up

Complaint Referred to: \_\_\_\_\_ for action.

Date: \_\_\_\_\_ Time: \_\_\_\_\_

Action Taken: checked street, running fine. Advised employees  
of Gas lite II to call plumber.

If the problem is on town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by the Public Works Dept. to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or the tenant so they can be aware of the situation.

All reports shall be turned in to the office on a daily basis.

Jeff Osborne  
Foreman/Employee in Charge (Signature)

Date: 10/23/76

SEWER MAIN/SERVICE PROBLEMS

Date: 1/16/76

Time: 9:28 A.M.

Name: Gas Lite II

Address: <sup>168</sup> 120 Pleasant St.

Complaint Received By: Henk Newton

Problem: Sewer - Backup

Complaint Referred to: K. Jenks for action.

Date: 1/16/76 Time: 11:30 A.M.

Action Taken: Robot out line - found grease and rags, Paper towels etc. - line was free when crew left. — 11:30 A.M. — Cleared by crew

If the problem is on town property, the employee in charge shall make contact with the property owner or tenant to explain what the problem was and the action taken by the Public Works Dept. to correct the stoppage.

If the problem is on private property, the employee in charge shall be responsible for notifying the property owner and or the tenant so they can be aware of the situation.

All reports shall be turned in to the office on a daily basis.

K. Jenks  
Foreman/Employee in Charge (Signature)

Date: 1/16/76

I. Gutzall opened cleanout cap in cellar allowing sewage to flood into the cellar before the Town checked the sewer main.