

AMITY STREET

1. 1. 1.

107470

## Well Completion Report

**BOARD OF HEALTH COPY**

СТАГОС



OFFICE OF  
BOARD OF HEALTH  
AMHERST. MASS.

April 1, 1953.

Amherst Board of Health,  
Amherst, Mass.

Dear Sirs:-

On Tuesday, March 17th, 1953 I investigated a proposed septic tank installation on the property of Mr. Edward Dzuiba of Amity St. Mr. Dzuiba pointed out to me that a main sewer line crossing his property has been over-flowing. This condition has existed for some time, and large quantities of raw sewerage have poured out over his land.

The Sewer Department has since dumped several loads of gravel on the manhole cover to prevent this overflow, but the sewerage has washed the gravel away.

Yours very truly,

*Richard M. Sturtevant*

Richard M. Sturtevant,  
Agent and Sanitarian.

S/a



1953

SEPTIC TANK INSPECTIONS

①

NAME	ADDRESS	DATE	REMARKS
DIUBA	AMITY ST	3/20/53	NOT APPROVED - REFERRED TO SPT OF SEWERS. DIUBA REQUESTED HEARING WITH D. OF H & SEWER COMM. RESULT - ALLOWED TO ENTER TOWN SYSTEM - PROVIDED HE INSTALS CHECK VALVE & GATE VALVE TO PREVENT BACKFLOW.
MALESKO JOHN	BECHERTOWN RD	3/26/53	APPROVED.
MILLER DONALD	SO EAST ST	3/26/53	APPROVED TWO INSTALLATIONS
MILLER	WEST ST	3/30/53	APPROVED
PETERSON CARL	SO PLEASANT	4/2/53	APPROVED
H. HATCH	W 1ST ST	7/10/53	APPROVED
BRACKMERE	WINDYWOOD LANE	7/10/53	APPROVED

18 INSTALLATIONS  
1 NOT APPROVED  
17 — " —

