


PATRICK L. L. L.  
10 Barry Circle



Town of



AMHERST Massachusetts

AMHERST HEALTH DEPARTMENT, 70 BOLTWOOD WALK, AMHERST, MA 01002  
(413) 256-4077

(413) 256-4033 ENVIRONMENTAL HEALTH SERVICES  
(413) 256-4053 (FAX)

April 23, 2002

Mr. Patrick McCabe  
10 Barry Circle  
Amherst, MA 01002

Dear Patrick,

I am in receipt of your letter dated April 4, 2002 requesting a waiver from the setback requirement of Title 5, Section 15.211(1) Minimum Setback Distances. This regulation requires a minimum distance of ten feet (10') between the cellar wall and septic tank.

It is my understanding with the expansion of your home you would encroach on the existing septic tank regulation by being less than ten feet (10') away.


This summer the Town of Amherst will begin the project of installing town sewer in your area. It is my understanding that you are willing to connect to the sewer when it is installed. Therefore, I am willing to support your request for the waiver under the condition that if the sewer expansion project in your area is canceled you are willing to conform to the Title 5 Regulation.

If you have any questions on this matter please feel free to call me at 256 - 4033.

Sincerely,

David Zarozinski  
Town Sanitarian





April 4, 2002

Mr. David Zarozinski  
Bangs Community Center  
70 Boltwood Walk  
Amherst, MA 01002-2351

Dear David,

We have been working with an architect over the last several months to prepare a plan which would include the expansion and remodeling of our kitchen. The construction would be scheduled to start next month. As I described by phone the only way we can expand is to put a seven foot addition to the north, which moves us in the direction of our septic tank, and into the setback zone of the septic tank. The good news though, is that we are scheduled to go onto town sewer this summer.

I visited with Jason in the town engineering department, who gave me copies of the Barry Circle sewer plan. He said that the work is expected to be done between June 1 and September 30, but could not give me a specific date for our street. It would be our expectation that we would connect to the new sewer once the Town of Amherst has given us permission, and cease using our septic system at that point. However for the couple of months until the new sewer is operational, our new construction would encroach into the 10-foot setback minimum between the new foundation and the existing tank.

Therefore, rather than pay to have the septic tank and field moved--only to have them sealed up a couple months later--we are requesting a waiver from the setback limits from your office. In this way, our construction could start next month, rather than being delayed until we go onto the new sewer line. Please let me know if there is anything else we must do.

Thank you for your assistance, and we look forward to hearing from you.

Cordially,




Pat McCabe  
10 Barry Circle  
Amherst, MA 01002

Phone: 253-3693

1000 2000  
1000 2000  
1000 2000  
1000 2000


483  
227  
2



MR DAVID ZARZEWSKI  
BANGS COMMUNITY CENTER  
70 BOLTWOOD WALK  
AMHERST, MA  
01002-2351


01002+2351











10 Barry Circle 6/13/03  
Crushed Septic Tank  
Karls Excavating.

#10 Barry Circle

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 75-18 Date 12/11/75 Fee \$3.00 Date Rec'd. 12/11/75 By DGF

Application is hereby made for a permit to Construct ( ) or Repair ( ) an Individual Sewage Disposal System at:

Location—Address SO. ORCHARD ACRES (BARRY CIRCLE) or Lot No. 23

Owner E. L. ROBERTS Address PELHAM MA

Contractor \_\_\_\_\_ Address \_\_\_\_\_

Type of Building SING. FAM. RESID Dimensions 25 X 63 Size Lot 42,927

Dwelling—No. of Bedrooms 4 Expansion Attic ( ) Garbage Grinder (Y)

Other \_\_\_\_\_ No. of persons 8 Showers ( )

Other fixtures \_\_\_\_\_

Town Water? YES Type of Well \_\_\_\_\_

Design Flow 50 gallons per person per day. Total daily flow 500 gallons

Septic Tank—Liquid capacity 1,200 gallons Dimensions: L \_\_\_\_\_ W \_\_\_\_\_ D \_\_\_\_\_

Disposal Trench—No. 1 Width 10 Total Length 60 Total leaching area 600 sq. ft.

Disposal Bed—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Dry Well—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Dimensions: \_\_\_\_\_ x \_\_\_\_\_ x \_\_\_\_\_

Other: Distribution box ( ) No. \_\_\_\_\_ Dosing tank ( )

(Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)

Percolation Test Results Performed by Randall G. Pund Date 5/2/75

Test Pit No. 1 21 minutes per inch Depth of Test Pit 36"

Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil Sand 6-m (SP) Depth to Ground Water 4.7'

Will disposal area be filled? No Cut down? No

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

SYSTEM TO BE LOCATED IN NORTHWEST CORNER OF LOT  
Application Approved by [Signature] Roberts Builders Inc. by 12/10/75 date

Application Disapproved for the following reasons: AS SHOWN ON PLOT KEEP SYSTEM SHALLOW.  
Barry Roberts 12-17-75 date

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE \_\_\_\_\_

Inspector \_\_\_\_\_

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 75-18 Permission is hereby granted E. L. ROBERTS to construct (X) or repair ( ) an

Individual Sewage Disposal System at LOT # 23 BARRY CIRCLE (SO. ORCHARD ACRES)

as shown on the application for Disposal Works Construction Permit No. 75-18

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 12-17-75


[Signature]  
Board of Health





David & Priscilla Smith  
Lot 19

Herbert  
Hutchings



Lot 27  
Everett Roberts

Lot 24  
Everett Roberts

Lot 23  
Everett Roberts

Barry Circle



BOARD OF HEALTH

TOWN OF AMHERST, MASSACHUSETTS

LOT 23, BARRY CIR

Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner LOUISE McCABE Address 10 BARRY CIR

Installer ROBERTS BROS Address WEST ST


Date Installation Inspected and Approved MAR 1976

Description of System: Tank Capacity: 1200

Leach Field ( ) Bed (X) Seepage Pit ( ) Square Feet: 640

Garbage Grinder Yes (X) No ( ) No. Bedrooms: 4 No. People 8

AS - BUILT PLAN:



PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.