


S12 Bay Rd





512 BAY RD

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 74-33 Date 5/1/74 Fee \$3.00 Date Rec'd. 5/1/74 By DGF

Application is hereby made for a permit to Construct (✓) or Repair () an Individual Sewage Disposal System at:

Location—Address 512 BAY ROAD or Lot No. _____

Owner ANDREW MIAZGA & MICHAEL Address SAME

Contractor ANDREWS ALUMINUM PRODUCTS Address SAME

Type of Building DWELLING Dimensions 50 X 58 Size Lot 200 X 700

Dwelling—No. of Bedrooms 7 Expansion Attic (✓) Garbage Grinder ()

Other _____ No. of persons _____ Showers ()

Other fixtures _____

Town Water? Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 700 gallons

Septic Tank—Liquid capacity 1500 gallons Dimensions: L 10'-4" W 5'-8" D 5'-4"

Disposal Trench—No. 1 Width 30' Total Length 30' Total leaching area 900 sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box (x) No. _____ Dosing tank ()

Depth of Soil Line Below finished grade at foundation _____

Percolation Test Results Performed by J. HART-HUNTLEY ASSOCIATES Date 4/11/74

Test Pit No. 1 1.3 minutes per inch Depth of Test Pit 2'-9"

Test Pit No. 2 _____ minutes per inch Depth of Test Pit 7'-0"

Description of Soil SAND & GRAVEL Depth to Ground Water _____

Will disposal area be filled? _____ Cut down? _____

On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

C. E. Maly Jr.
Application Approved by

Andrew Miazga Jr. 4/30/74
Owner or builder date
5-6-74
date

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER
Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE _____ Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT


No. 74-33
Permission is hereby granted ANDREW MIAZGA to construct (x) or repair () an Individual Sewage Disposal System at 512 BAY RD as shown on the application for Disposal Works Construction Permit No. 74-33


This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 5-6-74 C. E. Maly Jr.
Board of Health



Lot next to 512 Boy Road





OBSERVATION PITS



REQUESTED BY: ANDREW MIZOGA

DATE: 4/11/74

LOCATION: BY ROAD,
AMHERST


OBSERVER: JH

MAIL ADDRESS: _____



GROUND WATER NONE
PERC RATE: 1.3 min/in

GROUND WATER NONE
PERC RATE: _____



GROUND WATER _____
PERC RATE: _____



GROUND WATER _____
PERC RATE: _____

ALMER HUNTLEY, JR. & ASSOCIATES, INC.
 REGISTERED LAND SURVEYORS & CIVIL ENGINEERS
 238 BRIDGE STREET
 NORTHAMPTON, MASS.

