

AMHERST HEALTH DEPARTMENT

TITLE V FEES

Owner: Margaret Jewell

Site: 824 Bay Road  
LOT F

Percolation Test: \_\_\_\_\_ Per Lot

# \_\_\_\_\_ Date: \_\_\_\_\_

-----  
Disposal Works Construction Permit

Plan Review Date MAY 2, 89

Final Inspection Date 9/13/89  
PIPE FROM HOUSE TO TANK  
FLAT MUST RE-INSPECT

Subsequent Plan Review

Date \_\_\_\_\_

Date \_\_\_\_\_

Date \_\_\_\_\_

-----  
Reinspection of Installation

PIPE has Proper Date 9/13/89

Pitch OK Date \_\_\_\_\_

Wood 30.00 Date \_\_\_\_\_

FOR INSPECTION

1

2



489-7

TITLE V FEES

Owner: MARGARET Jewell

Site: LOT F Bay Road

Percolation Test: 824 Per Lot

# \_\_\_\_\_ Date: \_\_\_\_\_

# \_\_\_\_\_ Date: PC

# old \_\_\_\_\_ Date: 90

# \_\_\_\_\_ Date: PA

# \_\_\_\_\_ Date: Done

-----  
Disposal Works Construction Permit

Plan Review Date \_\_\_\_\_

Final Inspection Date \_\_\_\_\_

-----  
Subsequent Plan Review

Date \_\_\_\_\_

Date \_\_\_\_\_


Date \_\_\_\_\_

-----  
Reinspection of Installation

Date \_\_\_\_\_

Date \_\_\_\_\_

Date \_\_\_\_\_



NOV - 6 1989



# LEWIS & COOK SURVEYORS, INC.

P. O. BOX 1196  
BELCHERTOWN, MASSACHUSETTS 01007

RICHARD A. LEWIS, P.L.S.  
PRESIDENT  
413-323-7124

RICHARD L. COOK  
TREASURER  
413-283-7238

November 1, 1989


Board of Health  
Boltwood Walk  
Amherst, MA 01002

Dear Mr. Zarozinski,

(824) I have inspected the subsurface sewage disposal system at lot F, Bay Road on September 13, 1989 for Margaret Jewell. The system was substantially constructed as designed.

Yours truly,

Robert F. Sheehan, P.E.



No. 89-7

FEB. 90<sup>00</sup> ①

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Town of Amherst

Application for Disposal Works Construction Permit

Application is hereby made for a Permit to Construct (X) or Repair ( ) an Individual Sewage Disposal System at:

824 Bay Road Lot F
824 Margaret Jewell 818 Bay Rd Amherst, MA 01002

Type of Building Dwelling No. of Bedrooms 3 Expansion Attic ( ) Garbage Grinder (X)
Other - Type of Building No. of persons 6 Showers ( ) - Cafeteria ( )

Design Flow 55 gallons per person per day. Total daily flow 330 gallons.
Septic Tank - Liquid capacity 1000 gallons Length 96" Width 52" Diameter 48" Depth 48"
Disposal Trench - No. N/A Width Total Length Total leaching area 153.8 sq. ft.
Seepage Pit No. 1 Diameter 14' Depth below inlet 36" Total leaching area 131.8 sq. ft.

Percolation Test Results Performed by Lewis & Cook Surveyors, Inc Date April 14, 1989
Test Pit No. 1 2.0 minutes per inch Depth of Test Pit 45" Depth to ground water below 11'
Test Pit No. 2 2.0 minutes per inch Depth of Test Pit 96" Depth to ground water below 10 1/2'

Description of Soil see Attached sheets

Nature of Repairs or Alterations - Answer when applicable

Agreement: Insp. Dave Zarozinski
The undersigned agrees to install the aforescribed Individual Sewage Disposal System in accordance with the provisions of TITLE 5 of the State Sanitary Code - The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by the board of health

Signed Margaret P. Jewell 5/1/89



Application Approved By

Application Disapproved for the following reasons:

Permit No. 89-7 Issued Date

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Town of Amherst

Certificate of Compliance

THIS IS TO CERTIFY, That the Individual Sewage Disposal System constructed (X) or Repaired ( ) by

at LOT # F Bay Road
has been installed in accordance with the provisions of TITLE 5 of The State Sanitary Code as described in the application for Disposal Works Construction Permit No. 89-7 dated

THE ISSUANCE OF THIS CERTIFICATE SHALL NOT BE CONSTRUED AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORY.

DATE 7/13/89 Inspector David Zarozinski

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Town of Amherst

Disposal Works Construction Permit

Permission is hereby granted to Construct (X) or Repair ( ) an Individual Sewage Disposal System

at No. LOT F Bay Road as shown on the application for Disposal Works Construction Permit No. 89-7 Dated

DATE May 2, 1989 David Zarozinski for Robert P. Jewell Board of Health

CHECK OR FILL IN WHERE APPLICABLE

