

1205 BAY ROAD



1205

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 71-31 Date 12-8-71 Fee 3.00 Date Rec'd. 12-8-71 By [Signature]

Application is hereby made for a permit to Construct (X) or Repair () an Individual Sewage Disposal System at:

Location—Address BAY ROAD (1205) or Lot No. _____

Owner DAVID ROBINSON Address 60 EAST ST.

Contractor same Address _____

Type of Building RESIDENCE Dimensions _____ Size Lot _____

Dwelling—No. of Bedrooms 4 Expansion Attic () Garbage Grinder (X)

Other _____ No. of persons _____ Showers ()

Other fixtures _____

Town Water? YES Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 500 gallons

Septic Tank—Liquid capacity 1000 gallons Dimensions: L _____ W _____ D _____

Disposal Trench—No. _____ Width _____ Total Length _____ Total leaching area _____ sq. ft.

Disposal Bed—No. 1 Diameter 6 x 8 Depth below inlet 8 Total leaching area 278 sq. ft.

Dry Well—No. 1 Diameter 6 x 8 Depth below inlet 8 Dimensions: 6 x 8 x 8

Other: Distribution box () No. _____ Dosing tank () _____

(Depth of Soil Line Below finished grade at foundation _____)

Percolation Test Results Performed by KENDALL G. LUND Date 12-1-71

Test Pit No. 1 2 minutes per inch Depth of Test Pit 36"

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil SP- med-course sand Depth to Ground Water UNKNOWN > 15'

Will disposal area be filled? NO Cut down? NO

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

[Signature] David S. Robinson
Owner or builder
12-8-71
date

Application Approved by [Signature]
date

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed (X) or repaired () by KARL'S Exc. at 1205 BAY RD has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No.

71-31 dated 12-8-71

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE 12-8-71

Inspector [Signature]

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 71-31 Permission is hereby granted DAVID ROBINSON to construct (X) or repair () an Individual Sewage Disposal System at BAY ROAD (1205)


as shown on the application for Disposal Works Construction Permit No. 71-31

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 12-8-71

[Signature]
Board of Health

HARRIS Mt. Rd.



BAY ROAD