

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT**

No. 72-35 Date 10-19-72 Fee \$50 Date Rec'd. 10-19-72 By [Signature]

Application is hereby made for a permit to Construct (X) or Repair ( ) an Individual Sewage Disposal System at:

Location—Address 66 Chapel Rd. or Lot No. 5

Owner Mr. G. Roberge Address 938 Bay Rd. Amherst

Contractor KARLS ETC. Address \_\_\_\_\_

Type of Building \_\_\_\_\_ Dimensions \_\_\_\_\_ Size Lot \_\_\_\_\_

Dwelling—No. of Bedrooms 3 Expansion Attic ( ) Garbage Grinder ( )

Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( )

Other fixtures \_\_\_\_\_

Town Water? yes Type of Well \_\_\_\_\_

Design Flow 50 gallons per person per day. Total daily flow 300 gallons

Septic Tank—Liquid capacity 1000 gallons Dimensions: L \_\_\_\_\_ W \_\_\_\_\_ D \_\_\_\_\_

Disposal Trench—No. Bed Width 13' Total Length 21 Total leaching area 378 sq. ft.

Disposal Bed—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Dry Well—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Dimensions: \_\_\_\_\_ x \_\_\_\_\_ x \_\_\_\_\_

Other: Distribution box ( ) No. \_\_\_\_\_ Dosing tank ( )

(Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)

Percolation Test Results Performed by Miles J. Hubler PE Date 10-4-72

Test Pit No. 1 2 minutes per inch Depth of Test Pit 42"

Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil Medium sand SW Depth to Ground Water \_\_\_\_\_

Will disposal area be filled? no Cut down? no

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

[Signature] [Signature]  
 Application Approved by \_\_\_\_\_ Owner or builder \_\_\_\_\_ date 10-19-72  
 date \_\_\_\_\_

Application Disapproved for the following reasons:

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**CERTIFICATE OF COMPLIANCE**

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed (X) or repaired ( ) by KARLS ETC at LOT 5 CHAPEL RD has been constructed in accordance with the provisions of

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. 72-35 dated 10-19-72

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE Dec 15, 1972 Inspector [Signature]

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**DISPOSAL WORKS CONSTRUCTION PERMIT**


No. 72-35 Permission is hereby granted G Roberge to construct (X) or repair ( ) an Individual Sewage Disposal System at Lot 5 Chapel Rd

as shown on the application for Disposal Works Construction Permit No. 72-35

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 10-19-72 [Signature] Board of Health

(5)



Release to  
ground

Not less than 10'

Note: Dimensions shown are minimum.

SKETCH SHOWING  
SANITARY DISPOSAL FOR  
LOT #5

Chapel Rd. Amburst  
scale about 1" = 40'

10-14-72

To Bay Rd.

CHAPEL RD

See State Sanitary Code Art. XI for other specifications.