

51 E. EVERETT ROAD

50. E. LEVERETT ROAD

BOARD OF HEALTH
TOWN OF AMHERST, MASSACHUSETTS

REPAIR

Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner JOHN + NANCY DIVYER Address 51 E. LEUCRETT RD

Installer W.W. CHARK Address SHUTESBURY


Date Installation Inspected and Approved MARCH 17, 1983

Description of System: Tank Capacity: EXISTING 900?

Leach Field () Bed (X) Seepage Pit () Square Feet: 800

Garbage Grinder Yes () No (X) No. Bedrooms: 3 No. People 6

AS - BUILT PLAN:



PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.

