

233 EAST PLEASANT ST.



Title 5

Ed Smith [esmith@northamptonma.gov]

Sent: Monday, May 21, 2012 1:16 PM

Required: Smith, Edmund

When: Thursday, May 31, 2012 1:00 PM-2:00 PM.

Location: 233 East Pleasant

Show time as: Busy

Meeting status: Accepted

Description:

When: Thursday, May 31, 2012 1:00 PM-2:00 PM (GMT-05:00) Eastern Time (US & Canada).

Where: 233 East Pleasant


w/Alan Weiss

City of Northampton email messages are public records except when they fall under one of the specific statutory exemptions.

5/31/2012 - SYSTEM PASSES TITLE V.

- need to bill son + daughter (Harlan + Kate) Harvey

- Alan Weiss will send billing info





Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

received
 6.25.07



Owner information is required for every page.

233 East Pleasant Street
 Property Address
 Margaret and John Harvey (C/O Kate Harvey, daughter)
 Owner's Name
 Amherst MA 01002 5.23.2007
 City/Town State Zip Code Date of Inspection

Inspection results must be submitted on this form. Inspection forms may not be altered in any way.

Important:
 When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



A. General Information

1. Inspector:
 Alan E. Weiss
 Name of Inspector
 Cold Spring Environmental Consultants Inc.
 Company Name
 350 Old Enfield Road
 Company Address
 Belchertown MA 01007
 City/Town State Zip Code
 413.323.5957
 Telephone Number License Number

B. Certification

I certify that I have personally inspected the sewage disposal system at this address and that the information reported below is true, accurate and complete as of the time of the inspection. The inspection was performed based on my training and experience in the proper function and maintenance of on site sewage disposal systems. **I am a DEP approved system inspector pursuant to Section 15.340 of Title 5 (310 CMR 15.000).** The system:

- Passes Conditionally Passes Fails
- Needs Further Evaluation by the Local Approving Authority


 Inspector's Signature 5.23.2007
 Date

The system inspector shall submit a copy of this inspection report to the Approving Authority (Board of Health or DEP) within 30 days of completing this inspection. If the system is a shared system or has a design flow of 10,000 gpd or greater, the inspector and the system owner shall submit the report to the appropriate regional office of the DEP. The original should be sent to the system owner and copies sent to the buyer, if applicable, and the approving authority.

******This report only describes conditions at the time of inspection and under the conditions of use at that time. This inspection does not address how the system will perform in the future under the same or different conditions of use.**

001201



Commonwealth of Massachusetts
Title 5 Official Inspection Form
Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner information is required for every page.

233 East Pleasant Street
 Property Address
 Margaret and John Harvey (C/O Kate Harvey, daughter)
 Owner's Name
 Amherst MA 01002 5.23.2007
 City/Town State Zip Code Date of Inspection

B. Certification (cont.)

Inspection Summary: Check A,B,C,D or E / **always** complete all of Section D

A) System Passes:

- I have not found any information which indicates that any of the failure criteria described in 310 CMR 15.303 or in 310 CMR 15.304 exist. Any failure criteria not evaluated are indicated below.

Comments:

S, Tank level was good at inspection, System is unk age. (Town had no records). D. box levels were good and stone was clean and dry. Laundry should be connected from separate "surface pipe" with plumbers letter of confirmation. (To be Attached). Spoke with Town Sanitarian and Laundry and laundry sink connection is required. System is older and limited in size (sewer in street).

B) System Conditionally Passes:

- One or more system components as described in the "Conditional Pass" section need to be replaced or repaired. The system, upon completion of the replacement or repair, as approved by the Board of Health, will pass.

Answer yes, no or not determined (Y, N, ND) in the for the following statements. If "not determined," please explain.


- The septic tank is metal and over 20 years old* or the septic tank (whether metal or not) is structurally unsound, exhibits substantial infiltration or exfiltration or tank failure is imminent. System will pass inspection if the existing tank is replaced with a complying septic tank as approved by the Board of Health.

* A metal septic tank will pass inspection if it is structurally sound, not leaking and if a Certificate of Compliance indicating that the tank is less than 20 years old is available.

ND Explain:

- Observation of sewage backup or break out or high static water level in the distribution box due to broken or obstructed pipe(s) or due to a broken, settled or uneven distribution box. System will pass inspection if (with approval of Board of Health):

- broken pipe(s) are replaced
- obstruction is removed





Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street

Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)

Owner's Name

Amherst

City/Town

MA

State

01002

Zip Code

5.23.2007

Date of Inspection

Owner information is required for every page.

B. Certification (cont.)

B) System Conditionally Passes (cont.):

- [] distribution box is leveled or replaced

ND Explain:

- [] The system required pumping more than 4 times a year due to broken or obstructed pipe(s). The system will pass inspection if (with approval of the Board of Health):

- [] broken pipe(s) are replaced

- [] obstruction is removed

ND Explain:

C) Further Evaluation is Required by the Board of Health:

- [] Conditions exist which require further evaluation by the Board of Health in order to determine if the system is failing to protect public health, safety or the environment.

1. System will pass unless Board of Health determines in accordance with 310 CMR 15.303(1)(b) that the system is not functioning in a manner which will protect public health, safety and the environment:

- [] Cesspool or privy is within 50 feet of a surface water


- [] Cesspool or privy is within 50 feet of a bordering vegetated wetland or a salt marsh

2. System will fail unless the Board of Health (and Public Water Supplier, if any) determines that the system is functioning in a manner that protects the public health, safety and environment:

- [] The system has a septic tank and soil absorption system (SAS) and the SAS is within 100 feet of a surface water supply or tributary to a surface water supply.

- [] The system has a septic tank and SAS and the SAS is within a Zone 1 of a public water supply.

- [] The system has a septic tank and SAS and the SAS is within 50 feet of a private water supply well.





Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street

Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)

Owner's Name

Amherst

MA

01002

5.23.2007

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

B. Certification (cont.)

C) Further Evaluation is Required by the Board of Health (cont.):

- The system has a septic tank and SAS and the SAS is less than 100 feet but 50 feet or more from a private water supply well**.

Method used to determine distance:


** This system passes if the well water analysis, performed at a DEP certified laboratory, for coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis must be attached to this form.

3. Other:

D) System Failure Criteria Applicable to All Systems:

You must indicate "Yes" or "No" to each of the following for all inspections:

- Yes No Backup of sewage into facility or system component due to overloaded or clogged SAS or cesspool
Discharge or ponding of effluent to the surface of the ground or surface waters due to an overloaded or clogged SAS or cesspool
Static liquid level in the distribution box above outlet invert due to an overloaded or clogged SAS or cesspool
Liquid depth in cesspool is less than 6" below invert or available volume is less than 1/2 day flow
Required pumping more than 4 times in the last year NOT due to clogged or obstructed pipe(s). Number of times pumped:
Any portion of the SAS, cesspool or privy is below high ground water elevation.
Any portion of cesspool or privy is within 100 feet of a surface water supply or tributary to a surface water supply.





Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street

Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)

Owner's Name

Amherst

City/Town

MA

State

01002

Zip Code

5.23.2007

Date of Inspection

Owner information is required for every page.

B. Certification (cont.)

D) System Failure Criteria Applicable to All Systems (cont.):


- Yes No
Any portion of a cesspool or privy is within a Zone 1 of a public well.
Any portion of a cesspool or privy is within 50 feet of a private water supply well.
Any portion of a cesspool or privy is less than 100 feet but greater than 50 feet from a private water supply well with no acceptable water quality analysis.
The system is a cesspool serving a facility with a design flow of 2000gpd-10,000gpd.
The system fails. I have determined that one or more of the above failure criteria exist as described in 310 CMR 15.303, therefore the system fails.

E) Large Systems: To be considered a large system the system must serve a facility with a design flow of 10,000 gpd to 15,000 gpd.

For large systems, you must indicate either "yes" or "no" to each of the following, in addition to the questions in Section D.

- Yes No
the system is within 400 feet of a surface drinking water supply
the system is within 200 feet of a tributary to a surface drinking water supply
the system is located in a nitrogen sensitive area (Interim Wellhead Protection Area - IWPA) or a mapped Zone II of a public water supply well

If you have answered "yes" to any question in Section E the system is considered a significant threat, or answered "yes" in Section D above the large system has failed. The owner or operator of any large system considered a significant threat under Section E or failed under Section D shall upgrade the system in accordance with 310 CMR 15.304.





Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street

Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)

Owner's Name

Amherst

City/Town

MA

State

01002

Zip Code

5.23.2007

Date of Inspection

Owner information is required for every page.


C. Checklist

Check if the following have been done. You **must** indicate "yes" or "no" as to each of the following:

- | Yes | No | |
|-------------------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Pumping information was provided by the owner, occupant, or Board of Health |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Were any of the system components pumped out in the previous two weeks? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Has the system received normal flows in the previous two week period? |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Have large volumes of water been introduced to the system recently or as part of this inspection? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Were as built plans of the system obtained and examined? (If they were not available note as N/A) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Was the facility or dwelling inspected for signs of sewage back up? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Was the site inspected for signs of break out? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Were all system components, excluding the SAS, located on site? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Were the septic tank manholes uncovered, opened, and the interior of the tank inspected for the condition of the baffles or tees, material of construction, dimensions, depth of liquid, depth of sludge and depth of scum? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Was the facility owner (and occupants if different from owner) provided with information on the proper maintenance of subsurface sewage disposal systems? |

The **size and location of the Soil Absorption System (SAS)** on the site has been determined based on:

- | | | |
|-------------------------------------|--------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Existing information. For example, a plan at the Board of Health. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Determined in the field (if any of the failure criteria related to Part C is at issue approximation of distance is unacceptable) [310 CMR 15.302(5)] |





Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner information is required for every page.

233 East Pleasant Street
 Property Address
 Margaret and John Harvey (C/O Kate Harvey, daughter)
 Owner's Name
 Amherst MA 01002 5.23.2007
 City/Town State Zip Code Date of Inspection

D. System Information

Residential Flow Conditions:

Number of bedrooms (design): ? Number of bedrooms (actual): 4

DESIGN flow based on 310 CMR 15.203 (for example: 110 gpd x # of bedrooms): ?

Number of current residents: 1

Does residence have a garbage grinder? Yes No

Is laundry on a separate sewage system? [if **yes** separate inspection required] Yes No

Laundry system inspected? Yes No

Seasonal use? Yes No

Water meter readings, if available (last 2 years usage (gpd)): N/A

Sump pump? Yes No

Last date of occupancy: current
Date

Commercial/Industrial Flow Conditions:

Type of Establishment: N/A

Design flow (based on 310 CMR 15.203): N/A
Gallons per day (gpd)

Basis of design flow (seats/persons/sq.ft., etc.): N/A

Grease trap present? Yes No


Industrial waste holding tank present? Yes No

Non-sanitary waste discharged to the Title 5 system? Yes No

Water meter readings, if available: N/A

Last date of occupancy/use: N/A
Date

Other (describe): N/A





Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street

Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)

Owner's Name

Amherst

City/Town

MA

State

01002

Zip Code

5.23.2007

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

General Information

Pumping Records:

Source of information:

Owner: (2 yrs)

Was system pumped as part of the inspection?

Yes No

If yes, volume pumped:

1500 g
gallons

How was quantity pumped determined?

pumper

Reason for pumping:

T-5

Type of System:


- Septic tank, distribution box, soil absorption system
Single cesspool
Overflow cesspool
Privy
Shared system (yes or no) (if yes, attach previous inspection records, if any)
Innovative/Alternative technology. Attach a copy of the current operation and maintenance contract (to be obtained from system owner)
Tight tank. Attach a copy of the DEP approval.
Other (describe):

Approximate age of all components, date installed (if known) and source of information:

Unknown, NO town records avail. Laundry (& sink) 1' pipe to be connected to main system.

Were sewage odors detected when arriving at the site?

Yes No





Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street
 Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)
 Owner's Name

Amherst MA 01002 5.23.2007
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Building Sewer (locate on site plan):

Depth below grade: 1'+
 feet

Material of construction:

cast iron 40 PVC other (explain): _____

Distance from private water supply well or suction line: 10'
 feet

Comments (on condition of joints, venting, evidence of leakage, etc.):

Septic Tank (locate on site plan):

Depth below grade: 1'

Material of construction:

concrete metal fiberglass polyethylene other (explain)

If tank is metal, list age: _____
 years

Is age confirmed by a Certificate of Compliance? (attach a copy of certificate) Yes No

Dimensions: 8.5'X4.5'X4.5'

Sludge depth: 3"


Distance from top of sludge to bottom of outlet tee or baffle 46"

Scum thickness 3"

Distance from top of scum to top of outlet tee or baffle 6"

Distance from bottom of scum to bottom of outlet tee or baffle 12"

How were dimensions determined? Measured





Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street

Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)

Owner's Name

Amherst

City/Town

MA

State

01002

Zip Code

5.23.2007

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

Tank levels good. Structural integrity appeared good at time of inspection. (baffles in place),

Grease Trap (locate on site plan):

Depth below grade:

N/A

feet

Material of construction:

concrete

metal

fiberglass

polyethylene

other (explain):

Dimensions:

N/A

Scum thickness

N/A

Distance from top of scum to top of outlet tee or baffle

N/A

Distance from bottom of scum to bottom of outlet tee or baffle

N/A

Date of last pumping:

N/A

Date

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

N/A

Tight or Holding Tank (tank must be pumped at time of inspection) (locate on site plan):

Depth below grade:

N/A

Material of construction:

concrete


metal

fiberglass

polyethylene

other (explain):

N/A





Commonwealth of Massachusetts
Title 5 Official Inspection Form
Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street
 Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)
 Owner's Name

Amherst MA 01002 5.23.2007
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Tight or Holding Tank (cont.)

Dimensions: N/A

Capacity: N/A
 gallons

Design Flow: N/A
 gallons per day

Alarm present: Yes No

Alarm level: N/A Alarm in working order: Yes No

Date of last pumping: N/A
 Date

Comments (condition of alarm and float switches, etc.):
N/A

* Attach copy of current pumping contract (required). Is copy attached? Yes No

Distribution Box (if present must be opened) (locate on site plan):

Depth of liquid level above outlet invert @ inv.


Comments (note if box is level and distribution to outlets equal, any evidence of solids carryover, any evidence of leakage into or out of box, etc.):

Stone was dry & clean. Levels of liquid are at invert (one line out),

Pump Chamber (locate on site plan):

Pumps in working order: Yes No

Alarms in working order: Yes No





Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street

Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)

Owner's Name

Amherst

City/Town

MA
State

01002
Zip Code

5.23.2007
Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Comments (note condition of pump chamber, condition of pumps and appurtenances, etc.):

Soil Absorption System (SAS) (locate on site plan, excavation not required):

If SAS not located, explain why:


Type:

- leaching pits number: _____
- leaching chambers number: _____
- leaching galleries number: _____
- leaching trenches number, length: _____
- leaching fields number, dimensions: 20' x 10' ??
- overflow cesspool number: _____
- innovative/alternative system

Type/name of technology: _____

Comments (note condition of soil, signs of hydraulic failure, level of ponding, damp soil, condition of vegetation, etc.):

No Evidence of hydraulic failure. only 1 line out, system size is limited.





Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street
 Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)
 Owner's Name

Amherst MA 01002 5.23.2007
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Cesspools (cesspool must be pumped as part of inspection) (locate on site plan):

Number and configuration _____

Depth – top of liquid to inlet invert _____

Depth of solids layer _____

Depth of scum layer _____

Dimensions of cesspool _____

Materials of construction _____

Indication of groundwater inflow Yes No

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):

Privy (locate on site plan):


Materials of construction: N/A _____

Dimensions N/A _____

Depth of solids N/A _____

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):

N/A _____





Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street

Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)

Owner's Name

Amherst

City/Town

MA
State


01002
Zip Code


5.23.2007
Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Sketch Of Sewage Disposal System: Provide a sketch of the sewage disposal system including ties to at least two permanent reference landmarks or benchmarks. Locate all wells within 100 feet. Locate where public water supply enters the building.







Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

233 East Pleasant Street
 Property Address

Margaret and John Harvey (C/O Kate Harvey, daughter)
 Owner's Name

Amherst MA 01002 5.23.2007
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Site Exam:

- Check Slope
- Surface water
- Check cellar
- Shallow wells


Estimated depth to ground water: 4'+
 feet

Please indicate all methods used to determine the high ground water elevation:

- Obtained from system design plans on record
 If checked, date of design plan reviewed: n/A
 Date
- Observed site (abutting property/observation hole within 150 feet of SAS)
- Checked with local Board of Health - explain:
NO records avail.
- Checked with local excavators, installers - (attach documentation)
- Accessed USGS database - explain:

You **must** describe how you established the high ground water elevation:

Excavation dug to 3 ft below grade next to d. box.





- Elevation Contours
 - Index Contour
 - Intermediate Contour
 - - - Depression - Index
 - - - Depression - Intermediate
 - - - Obscured - Index
 - - - Obscured - Intermediate
 - - - Obscured Depression - Index
 - - - Obscured Depression - Int
- Elevation Model
 - High : 1,258.99'
 - Low : 128.56'
 - Elevations
 - - - Rail Lines
 - - - Trails
 - - - Miscellaneous Lines
 - Transportation
 - - - Pavement
 - - - Unpaved Road
 - - - Tree Cover

Horizontal Datum: MA Stateplane Coordinate System, Zone 4151, Datum NAD83, Feet

Planimetric basemap features compiled at 1"=40' and 1"=100' scale from April, 1999 Aerial Photography. Aerial Photography: April, 2004. Parcels compiled through a "best-fit" methodology to match the basemap; revisions are ongoing.

The information depicted on this map is for planning purposes only. It may not be adequate for legal boundary definition, regulatory interpretation, or property conveyance purposes.

THE TOWN OF AMHERST MAKES NO WARRANTIES, EXPRESSED OR IMPLIED, CONCERNING THE ACCURACY, COMPLETENESS, RELIABILITY, OR SUITABILITY OF THESE DATA. THE TOWN OF AMHERST DOES NOT ASSUME ANY LIABILITY ASSOCIATED WITH THE USE OR MISUSE OF THIS INFORMATION.

1" = 100 ft



