

To: Amherst Board of Health From: Paul M. Styspeck, P.E.

Date: March 1, 2006

Re: Lawrence Britt, #238 Flat Hills Road – Repaired Septic System

In accordance with Massachusetts Title V section 15.021 – Certificates of Compliance – I am writing to approve the installation of the new septic system for the above address. The system was installed by River Drive Excavating of Hadley. The required sub-grade inspection was performed and approved on February 23, 2006 by Raymond Mieczkowski, Registered Soil Evaluator. The system was inspected on March 1, 2006 by me prior to backfilling. In addition, please find attached schematic showing the 'as-built' location of the new septic system. All system components have been installed per Title Five regulations and all proposed pipe elevations were installed per design.

If you have any questions, please contact me at (413) 585-8188 or write to the above address. Also I can be reached at p.styspeck@verizon.net.


Sincerely,

Paul M. Styspeck, P.E.

Cc: River Drive Excavating

Lawrence Britt

Brian McHugh, FCRHRA



Town of



AMHERST Massachusetts

AMHERST HEALTH DEPARTMENT, 70 BOLTWOOD WALK, AMHERST, MA 01002 (413) 256-4077

> (413) 256-4033 ENVIRONMENTAL HEALTH SERVICES (413) 256-4053 (FAX)

## SUB-GRADE INSPECTION

ocation: #238 Flat Hills Rd
Property Owner: Lawrence Britt
certify that I have inspected the excavation to sub-grade of the proposed septic system eaching area prior placement of any fill of stone, or construction of any portion of the ystem.
further certify that:
<ul> <li>All 'A' and 'B' horizon soils (topsoils and subsoils) were removed in the area of the system.</li> <li>There was no evidence of ground water in the excavation.</li> <li>There was no evidence of "mottles" that would be in conflict with the findings of the deep hole soil profile.</li> <li>That the excavation was accomplished to the proper depth and in conformance with the approved plans.</li> </ul>
Paul Styspeck, P.E. Besigners Signature  Designers Signature
Designers Name Designers Signature
treet Address  Town, State, Zip Code
treet Address Town, State, Zip Code
413-585-8188
Celephone Number



6066-507

