

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT**

#213

No. 73-46 Date 5/14/73 Fee \$3.00 Date Rec'd. 5/14/73 By DGF

Application is hereby made for a permit to Construct (  ) or Repair ( ) an Individual Sewage Disposal System at:

Location—Address 213 Shantwood Drive East or Lot No. #64

Owner Donald A. Grant Address 27 Norfolk St. Northampton MA

01060

Contractor \_\_\_\_\_ Address \_\_\_\_\_

Type of Building Wood Frame Dimensions 36x24 Size Lot 20,400 sq. ft.

Dwelling—No. of Bedrooms (2) Expansion Attic ( ) Garbage Grinder ( ) yes

Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( )

Other fixtures \_\_\_\_\_

Town Water? yes Type of Well \_\_\_\_\_

Design Flow 50 gallons per person per day. Total daily flow 200 gallons

Septic Tank—Liquid capacity 1000 gallons Dimensions: L \_\_\_\_\_ W \_\_\_\_\_ D \_\_\_\_\_

Disposal Trench—No. 2 Width 3.0' Total Length 84 Total leaching area 252 sq. ft.

Disposal Bed—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Dry Well—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Dimensions: \_\_\_\_\_ x \_\_\_\_\_ x \_\_\_\_\_

Other: Distribution box ( ) No. \_\_\_\_\_ Dosing tank ( )

(Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)

Percolation Test Results Performed by Miles J. Huber PE Date 5-11-73

Test Pit No. 1 (10) minutes per inch Depth of Test Pit 7.0'

Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil coarse silt Depth to Ground Water 6.0'

Will disposal area be filled? \_\_\_\_\_ Cut down? \_\_\_\_\_

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

SYSTEM MUST BE 4' ABOVE GROUND WATER Donald A. Grant 5/14/73  
 Owner or builder date

Application Approved by [Signature] 5-16-73  
 date

Application Disapproved for the following reasons:

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**CERTIFICATE OF COMPLIANCE**

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of

INSTALLER  
 Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE \_\_\_\_\_ Inspector \_\_\_\_\_

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**DISPOSAL WORKS CONSTRUCTION PERMIT**

No. 73-46  
 Permission is hereby granted Donald Grant to construct (  ) or repair ( ) an Individual Sewage Disposal System at LOT 64 GRANTWOOD DR.

as shown on the application for Disposal Works Construction Permit No. 73-46

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 5-16-73 [Signature]  
 Board of Health

1944

1944

1944

Handwritten notes at the top left, including the number 1944.

Handwritten notes at the top right, including the number 1944.



1944

1944

1944



Large handwritten text in the middle of the page, possibly a title or a list of items.



Handwritten text in the lower middle section of the page.

1944

Handwritten text at the bottom left of the page.


1944

# DEEP SOIL LOGS

OWNER Donald A Grant

DATE 5-11-73


LOCATION Grantwood Drive Lot 64 OBSERVER Hubler



TRAVELER'S



TRAVELER'S



NATIONAL  
 GRADE ENGINEERING  
 CONSULTANTS

LOT # 64

PLAN SHOWING SANITARY  
 SEWAGE DISPOSAL FOR  
 LOT # 64 GRANTWOOD  
 DRIVE AMHERST

1" = 40'

5-11-73

by M.J. Hubler



NATIONAL

PLEASE REUSE BOTTLES

CONTAINING CONTENTS

Town of

COPY TO: EDWARDS PARKER - 4/13/74  
FISHER HOMES (BOB CHURMAN)

COPY OF PAGES 2 and 4  
TO Bob Chisholm 3/8/74

# AMHERST Massachusetts

TOWN HALL

BOARD OF HEALTH

Date: May 16, 1973

*STATEMENT OF UNDERSTANDING*

*BETWEEN THE AMHERST BOARD OF HEALTH*

*AND: Donald A. Grant*

*It is fully understood by both parties mentioned above that when the current ban on connections to the Amherst public sewer system is ended that:*

- 1. The use of the private sewage disposal system located at Grantwood Drive, East - Lot #64 address*

*allowed by the attached permit will be discontinued.*

- 2. That arrangements for securing a permit for connecting to the Town's sanitary sewer system will be completed within a reasonable period, and*

- 3. That the actual connection will be completed within 90 days of the lifting of the ban unless an extension is granted by the Amherst Board of Health.*

*Penalties allowed under provisions of Section XI of Chapter 83 of the General Laws of the Commonwealth may be invoked for failure to comply with this agreement.*

Signed:   
*For the Amherst Board of Health*

  
*Permittee*

Permit No. 73-46

Date of Issue May 16, 1973

10



BOARD OF HEALTH  
TOWN OF AMHERST, MASSACHUSETTS

Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner: R. CHISHOLM Address LOT 64 GRANTWOOD Dr.

Installer JACK FAIR. (J+R TRUCKING) Address \_\_\_\_\_


Date Installation Inspected and Approved 4/25/74

Description of System: Tank Capacity: 1000

Leach Field (X) Bed ( ) Seepage Pit ( ) Square Feet: 260

Garbage Grinder Yes (✓) No ( ) No. Bedrooms: 3 No. People 6

AS - BUILT PLAN:



PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.

11