

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT**

#217

No. 73-45 Date 5/14/73 Fee \$3.00 Date Rec'd. 5/14/73 By DGE

Application is hereby made for a permit to Construct (X) or Repair ( ) an Individual Sewage Disposal System at:

Location—Address 217 Grantwood Drive or Lot No. 84

Owner Donald G Grant Address \_\_\_\_\_

Contractor Donald G Grant From Address \_\_\_\_\_

Type of Building \_\_\_\_\_ Dimensions 36 x 24 Size Lot 20,000 sq ft

Dwelling—No. of Bedrooms 4 Expansion Attic ( ) Garbage Grinder ( ) yes

Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( ) \_\_\_\_\_

Other fixtures \_\_\_\_\_

Town Water? yes Type of Well \_\_\_\_\_

Design Flow 50 gallons per person per day. Total daily flow 400 gallons

Septic Tank—Liquid capacity 1000 gallons Dimensions: L \_\_\_\_\_ W \_\_\_\_\_ D \_\_\_\_\_

Disposal Trench—No. 2 Width 3.0' Total Length 84 Total leaching area 252 sq. ft.

Disposal Bed—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Dry Well—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Dimensions: \_\_\_\_\_ x \_\_\_\_\_ x \_\_\_\_\_

Other: Distribution box (X) No. \_\_\_\_\_ Dosing tank ( ) \_\_\_\_\_

(Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)

Percolation Test Results Performed by Miles J. Hubler PE Date 5-11-73

Test Pit No. 1 2 minutes per inch Depth of Test Pit 7.0

Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil sand Depth to Ground Water 6.0'

Will disposal area be filled? no Cut down? no

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

SYSTEM MUST BE KEPT AS ORIGINALS  
Donald G Grant Owner or builder 5/14/73  
 date

Application Approved by [Signature] 5/16/73  
 date

Application Disapproved for the following reasons:

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**CERTIFICATE OF COMPLIANCE**

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE \_\_\_\_\_ Inspector \_\_\_\_\_

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**DISPOSAL WORKS CONSTRUCTION PERMIT**

No. 73-45 Permission is hereby granted Donald Grant to construct (X) or repair ( ) an Individual Sewage Disposal System at Lot 84 Grantwood Dr

as shown on the application for Disposal Works Construction Permit No. 73-45

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE May 16, 1973 [Signature]  
 Board of Health

1002

100

Handwritten signature or name

X

11-11-73

Handwritten text

Handwritten text, possibly a signature or name

Handwritten signature or name


Handwritten text

11-11-73


Handwritten signature or name

Handwritten text

NATIONAL  
GRADE BASE BOARD  
COTTON CONTENT



→ To East Pleasant St.



PLAN SHOWING SANITARY  
SEWAGE DISPOSAL FOR LOT  
# 84 GRANTWOOD DRIVE  
AMHERST

1"=40'

5-11-73

by M.J. Hubler

COLTON COLLECT

BRIDGE BRIDGE BRIDGE

BRIDGE BRIDGE BRIDGE




# DEEP SOIL LOG

OWNER Donald Grant

DATE 5-11-73

LOCATION Grantwood Drive Lot 84

OBSERVER Hubler



COLLIER COMPANY

1000 EAST 125TH STREET

INDIANAPOLIS, IN.



Town of

AMHERST Massachusetts

TOWN HALL

BOARD OF HEALTH

Date: May 16, 1973

STATEMENT OF UNDERSTANDING

BETWEEN THE AMHERST BOARD OF HEALTH

AND: Donald A. Grant

It is fully understood by both parties mentioned above that when the current ban on connections to the Amherst public sewer system is ended that:

1. The use of the private sewage disposal system located at Grantwood Drive Lot #84 address

allowed by the attached permit will be discontinued.

2. That arrangements for securing a permit for connecting to the Town's sanitary sewer system will be completed within a reasonable period, and

3. That the actual connection will be completed within 90 days of the lifting of the ban unless an extension is granted by the Amherst Board of Health.

Penalties allowed under provisions of Section XI of Chapter 83 of the General Laws of the Commonwealth may be invoked for failure to comply with this agreement.

Signed: Chale [Signature]  
For the Amherst Board of Health

D. A. Grant  
Permittee

Permit No. 73-45

Date of Issue May 16, 1973

