

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

#227
 DCF

No. 73-49 Date MAY 16, 1973 Fee 3.00 Date Rec'd. MAY 15, 1973 By DCF

Application is hereby made for a permit to Construct (X) or Repair () an Individual Sewage Disposal System at:

Location—Address 27 Hawthornwood Drive, East or Lot No. 63

Owner H. G. Grant Address P.O. Box 623, Amherst

Contractor H. G. Grant Address P.O. Box 623

Type of Building Dwelling Dimensions _____ Size Lot _____

Dwelling—No. of Bedrooms 4 Expansion Attic () Garbage Grinder (X)

Other _____ No. of persons _____ Showers (X)

Other fixtures _____

Town Water? Yes Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 400 gallons

Septic Tank—Liquid capacity 1200 gallons Dimensions: L _____ W _____ D _____

Disposal Trench—No. 2 Width 3.0' Total Length 84' Total leaching area 252 sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box (X) No. _____ Dosing tank ()

(Depth of Soil Line Below finished grade at foundation _____)

Percolation Test Results Performed by Milo J. Huber Date 4-28-73

Test Pit No. 1 2 minutes per inch Depth of Test Pit 7.0'

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil _____ Depth to Ground Water none - 7'

Will disposal area be filled? yes above present gr. Cut down? _____

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the afordescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

See note on plan. RE. H. G. Grant 4/27/73
 Application Approved by C. E. Drake WATERLINE Owner or builder H. G. Grant date MAY 16, 1973
 date

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE _____ Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 73-49 Permission is hereby granted DONALD GRANT to construct (X) or repair () an Individual Sewage Disposal System at LOT 63 Hawthornwood

as shown on the application for Disposal Works Construction Permit No. 73-49

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE MAY 16, 1973 Board of Health

1947
MAY 12/47

MAY 12/47

MAY 12/47

1947

1947

X

MAY 12/47

MAY 12/47

MAY 12/47

1947

MAY 12/47

212 Michigan
CEB

CEB

1947
MAY 12/47

MAY 12/47

CEB

MAY 12/47


DEEP SOIL LOGS


OWNER D. A. Grant


DATE 4-28-73

LOCATION Grantwood Drive
Lot # 63

OBSERVER M. J. Hubler







Note: Encase waterline in 6" of concrete for 5' on each side of disposal seepage trenches.

Plan showing sanitary
Sewage Disposal For
Lot # 63 Grantwood Drive
Amherst Ma.

1" = 40'
by M.J. Hubler

4-28-73



Town of

AMHERST Massachusetts

TOWN HALL

BOARD OF HEALTH

Date: May 16, 1973

STATEMENT OF UNDERSTANDING

BETWEEN THE AMHERST BOARD OF HEALTH

AND: Donald A. Grant

It is fully understood by both parties mentioned above that when the current ban on connections to the Amherst public sewer system is ended that:

1. The use of the private sewage disposal system located at Grantwood Drive, East - Lot #63 address

allowed by the attached permit will be discontinued.

2. That arrangements for securing a permit for connecting to the Town's sanitary sewer system will be completed within a reasonable period, and

3. That the actual connection will be completed within 90 days of the lifting of the ban unless an extension is granted by the Amherst Board of Health.

Penalties allowed under provisions of Section XI of Chapter 83 of the General Laws of the Commonwealth may be invoked for failure to comply with this agreement.


Signed:

Chas. Ed. Kelly
For the Amherst Board of Health

D. A. Grant
Permittee

Permit No. 73-49

Date of Issue May 16, 1973



BOARD OF HEALTH
TOWN OF AMHERST, MASSACHUSETTS

Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner: ROBERT CHISHAM Address GRANTWOOD Dr.

Installer JACK FAIR Address _____

Date Installation Inspected and Approved 5-2-74


Description of System: Tank Capacity: 1000

Leach Field () Bed (X) Seepage Pit () Square Feet: 400

Garbage Grinder Yes (X) No () No. Bedrooms: 5 No. People 6



AS - BUILT PLAN:



PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.

