

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

#288

No. 73-54 Date 5/17/73 Fee \$3.00 Date Rec'd. 5/17/73 By DGF

Application is hereby made for a permit to Construct () or Repair () an Individual Sewage Disposal System at:

Location—Address 288 Grantwood Drive East or Lot No. #61
 Owner Donald A. Grant Address 27 Norfolk St Northampton, MA

Contractor _____ Address _____

Type of Building _____ Dimensions _____ Size Lot 20,200 SF.

Dwelling—No. of Bedrooms 4 Expansion Attic () Garbage Grinder (yes)

Other _____ No. of persons _____ Showers ()

Other fixtures yes

Town Water? yes Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 400 gallons

Septic Tank—Liquid capacity 1200 gallons Dimensions: L _____ W _____ D _____

Disposal Trench—No. _____ Width _____ Total Length _____ Total leaching area _____ sq. ft.

Disposal Bed—No. 1 Diameter 24 w. Depth below inlet 21 l. Total leaching area 504 sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box () No. _____ Dosing tank ()

(Depth of Soil Line Below finished grade at foundation _____)

Percolation Test Results Performed by Miles J. Huber PE Date 5-16-73

Test Pit No. 1 2 minutes per inch Depth of Test Pit 7 1/2'

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil _____ Depth to Ground Water 6 1/2'

Will disposal area be filled? no Cut down? no

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforedescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by [Signature] D. A. Grant Owner or builder 5/17/73 date
5-17-73 date

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.



DATE _____ Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 73-54
 Permission is hereby granted Donald Grant to construct (X) or repair () an Individual Sewage Disposal System at Lot #61 Grantwood Dr as shown on the application for Disposal Works Construction Permit No. 73-54

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE May 17/73 [Signature] Board of Health




Faint, illegible markings and bleed-through from the reverse side of the page, including what appears to be a signature or name.

DEEP SOIL LOGS

OWNER Donald Grant

DATE 5-16-73

LOCATION Grantwood Drive Lot 61 OBSERVER Hubler



COTTON CENTER
ERASE EASE BAND
NATIONAL




100% COTTON CONTENT

QUICK DRYING

JAMONITAM





J. MONTANA
CIVIL ENGINEER

Plan Showing Sanitary
Sewage Disposal for Lot #61
Grantwood Drive Amherst
1" = 40' 5-16-73



NATIONAL

ERASE EDGE BOARD

COTTON CONTENT

Town of

AMHERST Massachusetts

TOWN HALL

BOARD OF HEALTH

Date: May 17, 1973

STATEMENT OF UNDERSTANDING
BETWEEN THE AMHERST BOARD OF HEALTH

AND: Donald A. Grant

It is fully understood by both parties mentioned above that when the current ban on connections to the Amherst public sewer system is ended that:

- 1. The use of the private sewage disposal system located at Grantwood Drive, East - Lot #61 address*

allowed by the attached permit will be discontinued.

- 2. That arrangements for securing a permit for connecting to the Town's sanitary sewer system will be completed within a reasonable period, and*

- 3. That the actual connection will be completed within 90 days of the lifting of the ban unless an extension is granted by the Amherst Board of Health.*

Penalties allowed under provisions of Section XI of Chapter 83 of the General Laws of the Commonwealth may be invoked for failure to comply with this agreement.

Signed:

Charles D. Walsh
For the Amherst Board of Health

D. A. Grant
Permittee

Permit No. 73-54

Date of Issue May 17, 1973

