

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

#318

No. 73-47 Date 5/14/73 Fee \$3.00 Date Rec'd. 5/14/73 By DGF

Application is hereby made for a permit to Construct () or Repair () an Individual Sewage Disposal System at:

Location—Address 318 Grantwood Drive East or Lot No. #55

Owner Donald A. Grant Address 27 Norfolk St Northampton MA

Contractor _____ Address _____

Type of Building Wood Frame Dimensions 34 x 36 Size Lot 23,000 ± sq. ft.

Dwelling—No. of Bedrooms 3 Expansion Attic () Garbage Grinder () yes

Other _____ No. of persons _____ Showers () _____

Other fixtures _____

Town Water? yes Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 300 gallons

Septic Tank—Liquid capacity 1000 gallons Dimensions: L _____ W _____ D _____

Disposal Trench—No. 2 Width 3' Total Length 88 Total leaching area 264 sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box () No. _____ Dosing tank () _____

(Depth of Soil Line Below finished grade at foundation _____)

Percolation Test Results Performed by Miles J. Hubler PE Date 5-11-73

Test Pit No. 1 4 minutes per inch Depth of Test Pit 7.0'

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil Sand Depth to Ground Water 5.0'

Will disposal area be filled? _____ Cut down? _____

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

BOTTOM OF SYSTEM MUST BE NO MORE THAN 18" BELOW GRADE
 Application Approved by [Signature] Owner or builder Donald A. Grant date 5/14/73
 Application Disapproved for the following reasons: _____ date 5/16/73

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE _____ Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 73-47
 Permission is hereby granted Donald Grant to construct () or repair () an Individual Sewage Disposal System at Grantwood #55 as shown on the application for Disposal Works Construction Permit No. 73-47

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE May-16-1973 Board of Health [Signature]

1943

Handwritten notes and diagrams, including a large circle and various lines.

MUST BE NO MORE THAN 18 BEYOND THE

Handwritten notes and diagrams, including a large circle and various lines.

Directed General


12-17
1943

DEEP SOIL LOGS

OWNER Donald A. Grant

DATE 5-11-73

LOCATION Grantwood Drive Lot 55 OBSERVER Hubler



200-100-1000

THE UNIVERSITY OF MICHIGAN LIBRARY


ANN ARBOR, MICHIGAN 48106

DATE RECEIVED

LIBRARY



NATIONAL
BASE EAST BLDG
CONTRACT



PLAN SHOWING SANITARY
SEWAGE DISPOSAL FOR
LOT # 55 GRANTWOOD
DRIVE AMHERST

1"=40' 5-11-73

by M. J. Hubler



NATIONAL

RESEARCH BOARD

CONSTRUCTION

Town of

AMHERST Massachusetts

TOWN HALL

BOARD OF HEALTH

Date: May 16, 1973

STATEMENT OF UNDERSTANDING

BETWEEN THE AMHERST BOARD OF HEALTH

AND: Donald A. Grant

It is fully understood by both parties mentioned above that when the current ban on connections to the Amherst public sewer system is ended that:

- 1. The use of the private sewage disposal system located at Grantwood Drive, East - Lot #55 address*

allowed by the attached permit will be discontinued.

- 2. That arrangements for securing a permit for connecting to the Town's sanitary sewer system will be completed within a reasonable period, and*

- 3. That the actual connection will be completed within 90 days of the lifting of the ban unless an extension is granted by the Amherst Board of Health.*

Penalties allowed under provisions of Section XI of Chapter 83 of the General Laws of the Commonwealth may be invoked for failure to comply with this agreement.

Signed: For the Amherst Board of Health

D. A. Grant
Permittee

Permit No. 73-47

Date of Issue May 16, 1973

