

#284

BOARD OF HEALTH, AMHERST, MASSACHUSETTS

APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 67-8 Date 4-6-67 Fee 3.00 Date Rec'd. 4/25/67 By CEO/66

Application is hereby made for a permit to Construct (X) or Repair ( ) an Individual Sewage Disposal System at:

Location—Address 284 HARKNESS ROAD (BETWEEN R. OWEN + GARDNER) or Lot No. \_\_\_\_\_

Owner JOHN MAGGS Address JACKSON ST BELCHERTON

Contractor \_\_\_\_\_ Address \_\_\_\_\_

Type of Building \_\_\_\_\_ Dimensions 200 x 200 Size Lot 1 ACRE -

Dwelling—No. of Bedrooms 3 Expansion Attic NO Garbage Grinder NO  
Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( ) \_\_\_\_\_

Other fixtures \_\_\_\_\_  
Town Water? NO Type of Well DUG

Design Flow 25 gallons per person per day. Total daily flow \_\_\_\_\_ gallons

Septic Tank—Liquid capacity 900 gallons Dimensions: L \_\_\_\_\_ W \_\_\_\_\_ D \_\_\_\_\_

Disposal Trench—No. \_\_\_\_\_ Width \_\_\_\_\_ Total Length \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Disposal Bed—No. 1 Diameter 15 Depth below inlet \_\_\_\_\_ Total leaching area 300 sq. ft.

Dry Well—No. 1 Diameter 6 Depth below inlet 8' Dimensions: 6 x 6 x 8

Other: Distribution box ( ) No. \_\_\_\_\_ Dosing tank ( ) \_\_\_\_\_

(Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)

Percolation Test Results Performed by Shake Date 4-24-67

Test Pit No. 1 3 minutes per inch Depth of Test Pit 36"

Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil SAND + GRAVEL Depth to Ground Water \_\_\_\_\_

Will disposal area be filled? \_\_\_\_\_ Cut down? \_\_\_\_\_

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by CE Deale John A. Maggs Owner or builder Date 4-5-67  
date 4-21-67  
date

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of

INSTALLER  
Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.




DATE \_\_\_\_\_ Inspector \_\_\_\_\_

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 67-5 Permission is hereby granted JOHN MAGGS to construct (X) or repair ( ) an Individual Sewage Disposal System at HARKNESS RD

as shown on the application for Disposal Works Construction Permit No. 67-5  
This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE April 24 '67 CE Deale  
Board of Health



---

MARKNESS ROAD