

#348

38

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 3963 Date 7/11/63 Fee \$3.00 Date Rec'd. 7/12/63 By F.A.S.

Application is hereby made for a permit to Construct (✓) or Repair () an Individual Sewage Disposal System at:

Location—Address 348 Henry St. or Lot No. ? See sketch

Owner WALTER J. WYSOCKI Address BALCHERTOWN RD.

Contractor C.J. MILESZKO Address "

Type of Building RESIDENCE Dimensions 52x26 (Garage) Size Lot 6 ACRES +

Dwelling—No. of Bedrooms 4 Expansion Attic () Garbage Grinder ()

Other 1ST BATH - AUTO. WACHER + 1/2 BATH No. of persons 5 Showers (1)

Other fixtures 1ST BATH - AUTO. WACHER + 1/2 BATH

Town Water? No Type of Well ?

Design Flow 50 gallons per person per day. Total daily flow 250 gallons

Septic Tank—Liquid capacity 1200 gallons Dimensions: L 8 1/2' W 4' D 6'

Disposal Trench—No. _____ Width _____ Total Length _____ Total leaching area _____ sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. 2 Diameter 10x10 Depth below inlet 6' Dimensions: 10 x 10 x 8 deep.

Other: Distribution box (✓) No. _____ Dosing tank ()

(Depth of Soil Line Below finished grade at foundation 12")

Percolation Test Results Performed by F.A. SIINO Date 7/12/63

Test Pit No. 1 1 minutes per inch Depth of Test Pit _____

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil Boney gravel Depth to Ground Water _____

Will disposal area be filled? _____ Cut down? _____

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by F.A. Siino Walter J. Wysocki Owner or builder 7/11/63 date

Application Disapproved for the following reasons: _____ 7/12/63 date

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE _____ Inspector _____


38

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 3963 Permission is hereby granted Walter Wysocki to construct (✓) or repair () an Individual Sewage Disposal System at Henry St. as shown on the application for Disposal Works Construction Permit No. _____

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 7/12/63 F.A. Siino Board of Health



~~SO EAST ST~~
HENRY ST