

34 High Point Dr.



#34

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 69-10 Date 9-24-69 Fee 3.00 Date Rec'd. 9-24-69 By CEP

Application is hereby made for a permit to Construct (X) or Repair ( ) an Individual Sewage Disposal System at:

Location—Address LOT 8 34 HIGH POINT HILL or Lot No. \_\_\_\_\_

Owner ROY INDUSTRIES Address AMHERST MASSACHUSETTS

Contractor SMITH Address \_\_\_\_\_

Type of Building \_\_\_\_\_ Dimensions \_\_\_\_\_ Size Lot \_\_\_\_\_

Dwelling—No. of Bedrooms 4 Expansion Attic ( NO ) Garbage Grinder ( X )

Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( ) \_\_\_\_\_

Other fixtures \_\_\_\_\_

Town Water? NO Type of Well ARTESIAN

Design Flow 50 gallons per person per day. Total daily flow 450 gallons

Septic Tank—Liquid capacity 1200 gallons Dimensions: L \_\_\_\_\_ W \_\_\_\_\_ D \_\_\_\_\_

Disposal Trench—No. \_\_\_\_\_ Width \_\_\_\_\_ Total Length \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Disposal Bed—No. 1 Diameter 15X30 Depth below inlet \_\_\_\_\_ Total leaching area 450 sq. ft.

Dry Well—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Dimensions: \_\_\_\_\_ x \_\_\_\_\_ x \_\_\_\_\_

Other: Distribution box ( ) No. \_\_\_\_\_ Dosing tank ( ) \_\_\_\_\_

(Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)

Percolation Test Results Performed by Drake Date 9/24/69

Test Pit No. 1 7 minutes per inch Depth of Test Pit 36"

Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil FINE SAND CLAY Depth to Ground Water NO

Will disposal area be filled? NO Cut down? NO

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by CE Drake X Richard J. Wilbur Owner or builder date 9-24-69

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of

INSTALLER Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE \_\_\_\_\_ Inspector \_\_\_\_\_

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 69-10 Permission is hereby granted ROY INDUSTRIES to construct (X) or repair ( ) an

Individual Sewage Disposal System at LOT 8 HIGH POINT HILL

as shown on the application for Disposal Works Construction Permit No. 69-10

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 9-24-69 CE Drake Board of Health

