

83 High Point L.



**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT**

#83

No. 73-37 Date 5/9/73 Fee 3.- Date Rec'd. 5/9/73 By DGF

Application is hereby made for a permit to Construct ( ) or Repair ( ) an Individual Sewage Disposal System at:

Location—Address 83 HIGH POINT DRIVE or Lot No. 38

Owner ROY INDUSTRIES INC. Address CASHMAN ROAD SHUTESBURY

Contractor W.W. CLARK Address SHUTESBURY

Type of Building RESIDENCE Dimensions \_\_\_\_\_ Size Lot 40,200 sq'

Dwelling—No. of Bedrooms 4 Expansion Attic ( ) Garbage Grinder (  )

Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( )

Other fixtures \_\_\_\_\_

Town Water? NO Type of Well ART.

Design Flow 50 gallons per person per day. Total daily flow 400 gallons

Septic Tank—Liquid capacity 1200 gallons Dimensions: L 10'-0" W 5'-4" D 4'-10"

Disposal Trench—No. 1 Width 20' Total Length 40' Total leaching area 800 sq. ft.

Disposal Bed—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Dry Well—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Dimensions: \_\_\_\_\_ x \_\_\_\_\_ x \_\_\_\_\_

Other: Distribution box ( ) No. \_\_\_\_\_ Dosing tank ( )

(Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)

Percolation Test Results Performed by HUNTLOY ENGINEERING Date 4/17-19/73

Pipe - Test Pit No. 1 10.4 minutes per inch Depth of Test Pit 3'10"

Open - Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil G. TM Depth to Ground Water 5'6"??

Will disposal area be filled? See notes Cut down? \_\_\_\_\_

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the afordescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

\* System must be 4' ABOVE MAX GROUNDWATER ROY INDUSTRIES INC BY 5/9/73  
at edge Owner or builder date

Application Approved by C. O. Dush with 2 mcs. 5-14-73  
 date

Application Disapproved for the following reasons:

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**CERTIFICATE OF COMPLIANCE**

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE \_\_\_\_\_

Inspector \_\_\_\_\_

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS**  
**DISPOSAL WORKS CONSTRUCTION PERMIT**

No. 73-37


Permission is hereby granted Roy Industries Inc to construct (  ) or repair ( ) an Individual Sewage Disposal System at Lot 38, High Point 83 High Point as shown on the application for Disposal Works Construction Permit No. 73-37

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.


DATE MAY 14/1973

C. O. Dush  
 Board of Health






NOTE (1) PERF. PIPE TO BE 6' C.C. STATE MAY  
 (2) ALL WORK TO BE DONE IN ACCORDANCE WITH THE STATE SANITARY CODE ARTICLE VI



83 HIGH POINT DRIVE  
 PLAN OF PROPOSED  
 SEWAGE DISPOSAL FIELD  
 AMHERST, MASS.  
 PREPARED FOR 1"=40' 5/4/73 EAP  
 ROY INDUSTRIES INC.



**ALMER HUNTLEY, JR. & ASSOCIATES, INC.**  
 REGISTERED LAND SURVEYORS & CIVIL ENGINEERS  
 238 BRIDGE STREET  
 NORTHAMPTON, MASS.

