

101 High Point Dr.




No. 90-16

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Town OF Amherst

Application for Disposal Works Construction Permit



Pd 160.00  
\$41567

Application is hereby made for a Permit to Construct ( ) or Repair (  ) an Individual Sewage Disposal

System at: High Point

101 Juniper Lane  
Location - Address

Lot # 31 Parcel 61  
or Lot No.

Betty Kravetz  
Owner

31 Juniper Lane Amherst, MA 01002  
Address

Bostley Sanitary Service  
Installer

Greenfield, MA  
Address

Type of Building \_\_\_\_\_ Size Lot ~45,000 Sq. feet

Dwelling  No. of Bedrooms 4 Expansion Attic (No) \_\_\_\_\_ Garbage Grinder (No) \_\_\_\_\_

Other — Type of Building \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( ) — Cafeteria ( )

Other fixtures \_\_\_\_\_

Design Flow \_\_\_\_\_ 11.0 gallons per person per day. Total daily flow \_\_\_\_\_ 440 gallons.

Septic Tank  Liquid capacity 1000 gallons Length 8' Width 5' Diameter \_\_\_\_\_ Depth 4'

Disposal Trench — No. \_\_\_\_\_ Width \_\_\_\_\_ Total Length \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Seepage Pit No. 2 Diameter 10' x 16' Depth below inlet 6' Total leaching area 944 sq. ft.

Other Distribution box (Yes) \_\_\_\_\_ Dosing tank ( ) \_\_\_\_\_

Percolation Test Results Performed by R. Scott, P.E. with D. Zagorski, R. H. Roth Date 11-27-90

Test Pit No. 1. 11.7 minutes per inch Depth of Test Pit 138" Depth to ground water DRY

Test Pit No. 2. \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_ Depth to ground water \_\_\_\_\_

Description of Soil To 4" TOPSOIL; To 20" SUBSOIL; To 138" DEPTH FINE SANDY GREY TILL.

Nature of Repairs or Alterations — Answer when applicable REPLACE LEACH FACILITY AND PIPING FROM SEPTIC TANK TO LEACH PIT.

Agreement: The undersigned agrees to install the aforescribed Individual Sewage Disposal System in accordance with the provisions of TITLE 5 of the State Environmental Code — The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by the board of health.

Signed Betty Kravetz Date 12/17/90

Application Approved By David Zagorski for Robert H. Roth Date 12/16/90

Application Disapproved for the following reasons: \_\_\_\_\_

Permit No. 90-16 Issued \_\_\_\_\_ Date \_\_\_\_\_

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Town OF Amherst

Certificate of Compliance

THIS IS TO CERTIFY, That the Individual Sewage Disposal System constructed ( ) or Repaired (  )

by Bostley Sanitary Service

at 31 Juniper Lane (Lot 31)

has been installed in accordance with the provisions of TITLE 5 of The State Environmental Code as described in the application for Disposal Works Construction Permit No. 90-16 dated \_\_\_\_\_

**THE ISSUANCE OF THIS CERTIFICATE SHALL NOT BE CONSTRUED AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORY.**

DATE 5/16/91 Inspector David Zagorski

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Town OF Amherst

No. 90-16

FEE 160.00  
\$41567

Disposal Works Construction Permit

Permission is hereby granted \_\_\_\_\_

to Construct ( ) or Repair (  ) an Individual Sewage Disposal System

at No. 31 Juniper Lane

as shown on the application for Disposal Works Construction Permit No. 90-16 Dated 12/16/90

DATE 12/16/90 Board of Health David Zagorski for Robert H. Roth

CHECK OR FILL IN WHERE APPLICABLE

