

APPLICATION FOR PERMIT TO CONSTRUCT OR REPAIR
A PRIVATE SEWAGE DISPOSAL SYSTEM

#343

TO: THE BOARD OF HEALTH, AMHERST, MASS.

No. 13-61
35030
~~53443~~
(phone)

Adams, Lawrence of 961 No Pleasant (owner's name) (address) (phone)

hereby applies for a permit to construct or repair a private disposal system for a Residence (residence, store, etc.)

which will be located at Swerett Rd (East Side) to be installed by

Tuttle (name) (address) (phone)

Builder is A. Cullin Plumber is Shojiman

Description of lot, building and fixtures as follows:

Lot: Dimensions 200x200' 200x200' Type of Soil Mud Well or Town Water? Well

Distance to Town Sewer Miles Depth to Ground Water 9' Kind of Well Shy

Will Lot be Graded? No By Filling or Removing Soil?

Building: Dimensions 36x24 No. Bedrooms No. Occupants 6

Fixtures: No. Toilets 1 Urinals Wash Basins 1 Bathtubs

Showers 1 Kitchen Sinks 1 Garbage Grinders No

Auto Dishwasher No Auto. Clotheswasher ye Other (basement) None

(On reverse side show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

I certify that the above information is correct and that I will notify the Board of Health if any conditions are changed. I also declare that I have read and understand all the rules and regulations applying hereto and will comply with all requirements and stipulations as included in a permit if issued to me.

Date Aug 21, 1961 \$300 mid 9/1/61 JAS (Signature of Applicant) A.E. Cullin

PERMIT TO CONSTRUCT OR REPAIR A PRIVATE SEWAGE DISPOSAL SYSTEM

L. Adams is hereby granted permission to proceed with the construction or repair of private sewage disposal system with the following minimum requirements:

Septic Tank: Must be of Cement and of 900 Gals. Liquid Capacity.

Leaching System: Trenches of not less than Sq. Ft. bottom area.


Dr well ft. bottom area and ft. below the inlet.

Other Leaching Bed - 400 sq. ft Area (15x27') or equivalent

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

G. G. Sims for the Board of Health date

Inspected Approved OK



Levenett Rd

