

#93

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 73-20 Date 4/30/73 Fee \$3.00 Date Rec'd. 4/30/73 By DGF

Application is hereby made for a permit to Construct (X) or Repair ( ) an Individual Sewage Disposal System at:

Location—Address So. Market Hill Road 1/4 Mi. E. Henry St or Lot No. 79  
Owner Raymond Ashby Address 87 Market Hill Rd. Amherst MA.

Contractor \_\_\_\_\_ Address \_\_\_\_\_  
Type of Building \_\_\_\_\_ Dimensions \_\_\_\_\_ Size Lot 60,000 sq. ft.  
Dwelling—No. of Bedrooms 3 Expansion Attic ( ) Garbage Grinder ( )  
Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( )  
Other fixtures \_\_\_\_\_  
Town Water? yes Type of Well \_\_\_\_\_

Design Flow 50 gallons per person per day. Total daily flow 300 gallons  
Septic Tank—Liquid capacity 1000 gallons Dimensions: L 100 W 100 D 300  
Disposal Trench—No. 2 Width 3' Total Length 82 Total leaching area 246 sq. ft.  
Disposal Bed—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.  
Dry Well—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Dimensions: \_\_\_\_\_ x \_\_\_\_\_ x \_\_\_\_\_  
Other: Distribution box ( ) No. \_\_\_\_\_ Dosing tank ( )

(Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)  
Percolation Test Results Performed by Miles J. Hubler PE Date 4-17-73  
Test Pit No. 1 6 minutes per inch Depth of Test Pit 8'  
Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil Silty sand Depth to Ground Water 4.0'  
Will disposal area be filled? \_\_\_\_\_ Cut down? \_\_\_\_\_  
(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

CURTAIN DRAWN TO  
Application Approved by Raymond Ashby Owner or builder Date 4/30/73  
BE INSTALLED TO LOWER WATER TABLE  
Snow on plan  
Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
CERTIFICATE OF COMPLIANCE


THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of \_\_\_\_\_ INSTALLER Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_ The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.  
DATE \_\_\_\_\_ Inspector \_\_\_\_\_

BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 73-20  
Permission is hereby granted Raymond Ashby to construct (X) or repair ( ) an Individual Sewage Disposal System at 79 Market Hill Rd as shown on the application for Disposal Works Construction Permit No. 73-20

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE May 2/73 Board of Health




# DEEP SOIL LOGS

OWNER Raymond E. Ashby et ux


DATE 4-17-73


LOCATION Market Hill Road

OBSERVER M. J. Hubler



BOARD OF HEALTH  
AMHERST, MASS.





Note: Keep trenches at 24" depth.

Plan showing Sanitary  
Sewage Disposal for Lot  
on Market Hill Road Amherst  
Scale 1"=40'

4-17-73  
by M.J. Hubler

Revised 4/27/73

Handwritten horizontal line



Handwritten horizontal line



Handwritten text, possibly "ALV"

88-20

JUN 13 1988

#115

FEE \$90



THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

TOWN OF AMHERST MASS

Application for Disposal Works Construction Permit

Application is hereby made for a Permit to Construct (X) or Repair ( ) an Individual Sewage Disposal System at:

MARKET HILL ROAD CUSHMAN MASS LOT 1
M. STOKES Location - Address 87 MARKET HILL RD or Lot No. CUSHMAN MASS
Owner Address

Type of Building 4 bedrm Dwelling - No. of Bedrooms Expansion Attic (-) Garbage Grinder (-)
Other - Type of Building Resident No. of persons 2 sample Showers (3) - Cafeteria (-)
Other fixtures 3 BATHROOMS FULL BMT
Design Flow 110 gallons per person per day. Total daily flow 990 gallons.
Septic Tank - Liquid capacity 1200 gallons Length 12'6" Width 5'0" Diameter Depth 5'0"
Disposal Trench - No. 2 Width 2'0" Total Length 40' Total leaching area sq. ft.
Seepage Pit No. Diameter Depth below inlet 16" Total leaching area sq. ft.
Other Distribution box (1) Dosing tank (-) bottom 160FT2 siren wall 212.8 FT2
Percolation Test Results Performed by W.J. SIERUTA Date 3/13/88
Test Pit No. 1 4.0 minutes per inch Depth of Test Pit 120" Depth to ground water 108"
Test Pit No. 2 minutes per inch Depth of Test Pit Depth to ground water
Description of Soil TP1-1 0-9" OTS 4"-20" GRAVEL WITH ROOTS
TILL 76-130 TILL WITH COBBLES H2O @ 108 TP1-2
0-4" OTS 4"-21" GRAVEL WITH ROOTS 21-74 SAND
Nature of Repairs or Alterations - Answer when applicable TILL 74-130 TILL WITH COBBLES H2O @ 110"

Agreement: The undersigned agrees to install the aforescribed Individual Sewage Disposal System in accordance with the provisions of TITLE 5 of the State Sanitary Code - The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by the board of health.

Signed Lou Stoney Date
Application Approved By DP for Amherst Health Dept. Date 4/20/88

Application Disapproved for the following reasons:
Date

Permit No. 88-20 Issued Date

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

OF

Certificate of Compliance

THIS IS TO CERTIFY, That the Individual Sewage Disposal System constructed (X) or Repaired ( ) by TIDIANE Installer at 87 MARKET HILL ROAD has been installed in accordance with the provisions of TITLE 5 of The State Sanitary Code as described in the application for Disposal Works Construction Permit No. 88-20 dated

THE ISSUANCE OF THIS CERTIFICATE SHALL NOT BE CONSTRUED AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORY.

DATE May 12 1988 Inspector [Signature]

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

No. 88-20 Town OF Amherst FEE \$90 pd


Disposal Works Construction Permit

Permission is hereby granted to Construct (X) or Repair ( ) an Individual Sewage Disposal System at No. M. Stokes Market Hill Rd Lot #1 Street

as shown on the application for Disposal Works Construction Permit No. 88-20 Dated for Amherst Health Dept. DP Pickel Board of Health

DATE 6/20/88

CHECK OR FILL IN WHERE APPLICABLE





88-20

\$90

No. 88-20

FEE

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

TOWN OF AMHERST MASS

JUN 13 1988



Application for Disposal Works Construction Permit

System hereby made for a Permit to Construct (X) or Repair ( ) an Individual Sewage Disposal System at

MARKET HILL ROAD CUSHMAN MASS LOT 1
M. STOKES Location-Address 87 MARKET HILL RD or Lot No. CUSHMAN MASS
Owner Address

Type of Building 4 bedroom Dwelling - No. of Bedrooms Expansion Attic (-) Garbage Grinder (-)
Other - Type of Building 100 sq ft No. of persons 8 Showers (3) - Cafeteria (-)
Other fixtures 3 BATHROOMS FULL BMT

Design Flow 110 gallons per person per day. Total daily flow 990 gallons.
Septic Tank - Liquid capacity 1500 gallons Length 12'0" Width 5'0" Diameter Depth 5'0"
Disposal Trench - No. 2 Width 2'0" Total Length 40' Total leaching area sq. ft.
Seepage Pit No. Diameter Depth below inlet 10" Total leaching area sq. ft.

Other Distribution box (1) Dosing tank (-) bottom 100 FT 2 SIRENAD 212.8 FT 2
Percolation Test Results Performed by W.J. SIERUTA Date 3/18/88
Test Pit No. 1 4.0 minutes per inch Depth of Test Pit 60" Depth to ground water 102"
Test Pit No. 2 minutes per inch Depth of Test Pit Depth to ground water

Description of Soil 20-50 WELL GRADED GRANUL 50-70 SANDY
TILL 70-130 TILL WITH COBBLES H2O @ 108 TP-2
0-9" OTS 4"-21 GRANUL WITH ROOTS 21-74 SAND
Nature of Repairs or Alterations - Answer when applicable TILL 74-130 TILL WITH
COBBLES H2O @ 110"

Agreement: The undersigned agrees to install the aforescribed Individual Sewage Disposal System in accordance with the provisions of TITLE 5 of the State Sanitary Code - The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by the board of health.
Signed Lou Stoy
Application Approved By [Signature] Date 1/20/88
Application Disapproved for the following reasons:

Permit No. 88-20 Issued Date

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

TOWN OF Amherst

Certificate of Compliance

THIS IS TO CERTIFY, That the Individual Sewage Disposal System constructed (X) or Repaired ( ) by T. D. Land at 87 Market Hill Rd Amherst Mass has been installed in accordance with the provisions of TITLE 5 of The State Sanitary Code as described in the application for Disposal Works Construction Permit No. 88-20 dated

THE ISSUANCE OF THIS CERTIFICATE SHALL NOT BE CONSTRUED AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORY.

DATE May 19, 89 Inspector [Signature]

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

No. 88-20 Town OF Amherst FEE \$90

Disposal Works Construction Permit

Permission is hereby granted to Construct (X) or Repair ( ) an Individual Sewage Disposal System at No. M. Stokes Market Hill Rd Lot #1 as shown on the application for Disposal Works Construction Permit No. 88-20 Dated

DATE 6/20/89 Board of Health

CHECK OR FILL IN WHERE APPLICABLE



THE UNIVERSITY OF  
CALIFORNIA LIBRARY