

15 Mechanic St.

BOARD OF HEALTH, AMHERST, MASSACHUSETTS

APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 68-10 Date July 31, 1968 Fee 8.00 Date Rec'd. July 31, 1968 By CEH

Application is hereby made for a permit to Construct  or Repair  an Individual Sewage Disposal System at:

Location—Address LOT # 1 NUTTING MANOR or Lot No. \_\_\_\_\_

Owner SANDERS + ROBERGE Address Bay Rd

Contractor Karl Konigsmeyer Address River Drive N. Amherst

Type of Building \_\_\_\_\_ Dimensions \_\_\_\_\_ Size Lot 36,400

Dwelling—No. of Bedrooms 4 Expansion Attic NO Garbage Grinder  Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( ) \_\_\_\_\_

Other fixtures \_\_\_\_\_ Town Water? YES Type of Well \_\_\_\_\_

Design Flow 25 gallons per person per day. Total daily flow 600 gallons

Septic Tank—Liquid capacity 1200 gallons Dimensions: L \_\_\_\_\_ W \_\_\_\_\_ D \_\_\_\_\_

Disposal Trench—No. \_\_\_\_\_ Width \_\_\_\_\_ Total Length \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.

Disposal Bed—No. 1 Diameter 15x40 Depth below inlet \_\_\_\_\_ Total leaching area 400 sq. ft.

Dry Well—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Dimensions: \_\_\_\_\_ x \_\_\_\_\_ x \_\_\_\_\_

Other: Distribution box  No. 1 Dosing tank ( ) \_\_\_\_\_ (Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)

Percolation Test Results Performed by Drake Date July 30 '68

Test Pit No. 1 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_

Description of Soil SAND WITH CLAY Depth to Ground Water 6'

Will disposal area be filled? YES Cut down? \_\_\_\_\_

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

System to be filled  
Application Approved by CEH Owner or builder Richard G. Roberge 1-31-68 date

Application Disapproved for the following reasons: \_\_\_\_\_ date 7-31-68

BOARD OF HEALTH, AMHERST, MASSACHUSETTS

CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE \_\_\_\_\_ Inspector \_\_\_\_\_

BOARD OF HEALTH, AMHERST, MASSACHUSETTS

DISPOSAL WORKS CONSTRUCTION PERMIT


No. 68-10 Permission is hereby granted SANDERS ROBERGE to construct  or repair ( ) an Individual Sewage Disposal System at LOT # 1 NUTTING MANOR

as shown on the application for Disposal Works Construction Permit No. 68-10

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE July 31, 1968 Board of Health CEH

DEPARTMENT OF THE ARMY  
ENGINEERING CENTER  
FORT BELLEVILLE, ILLINOIS



DEPARTMENT OF THE ARMY  
ENGINEERING CENTER

DEPARTMENT OF THE ARMY  
ENGINEERING CENTER