

BOARD OF HEALTH #480 ~~Repair~~

TOWN OF AMHERST, MASSACHUSETTS

480 Middle St

Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner COURTNEY GORDON Address 480 Middle St

Installer KARLS EXCAVATING Address RIVER DR. HADLEY


Date Installation Inspected and Approved 9-12-83

Description of System: Tank Capacity: EXISTING 1200

Leach Field ( ) Bed (:X) Seepage Pit ( ) Square Feet: 800

Garbage Grinder Yes ( ) No ( ) No. Bedrooms: 4 No. People 8

AS - BUILT PLAN:



PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.

