

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

#570

No. 79-9 Date 4-25-79 Fee 17.5 Date Rec'd. 4-25-79 By [Signature]

Application is hereby made for a permit to Construct () or Repair () an Individual Sewage Disposal System at:

Location—Address Middle St. Amherst or Lot No. 3

Owner Walter & Debbie Kopeck Address 2 Eaton Ct. Amherst

Contractor Walter Kopeck Jr. (River Dr. Exc) Address 2 Eaton Ct. Amherst

Type of Building 2 storey house Dimensions _____ Size Lot 1.118 Acres ±

Dwelling—No. of Bedrooms 4 Expansion Attic () Garbage Grinder ()

Other _____ No. of persons 4 Showers ()

Other fixtures _____

Town Water? yes Type of Well _____

Design Flow 55 gallons per person per day. Total daily flow 440 gallons

Septic Tank—Liquid capacity 1500 gallons Dimensions: L 9 W 4 D 5

Disposal Trench—No. _____ Width _____ Total Length _____ Total leaching area _____ sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. 2 Diameter 6 Depth below inlet 6 Dimensions: _____ x _____ x _____

Other: Distribution box () No. _____ Dosing tank ()

(Depth of Soil Line Below finished grade at foundation _____)

Percolation Test Results Performed by Fred Fikus on File Date 4-25-79

Test Pit No. 1 2 minutes per inch Depth of Test Pit 10'

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil SAND Depth to Ground Water None at 10'

Will disposal area be filled? NO Cut down? _____

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by [Signature] Owner or builder [Signature] date 4-25-79
 date

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE _____ Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 79-9 Permission is hereby granted River Dr. Exc. For W. Kopeck Jr to construct () or repair () an Individual Sewage Disposal System at Lot #3 Middle St - Middle St as shown on the application for Disposal Works Construction Permit No. 79-9

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 4-25-79 Board of Health [Signature]

1950

STATE OF TEXAS

COUNTY OF DALLAS


Know all men by these presents that _____ (Name) of the County of _____ State of _____ do hereby certify that _____ (Name) is the owner of _____ (Property) located at _____ (Address) in the County of _____ State of _____

and that the same is subject to a lien in favor of _____ (Name) for the sum of _____ Dollars (\$ _____) which said sum is due and payable to said _____ (Name) on or before _____ (Date) 19____.

Witness my hand and seal of office this _____ day of _____ 19____.

County Clerk

Notary Public



LEO & ANN H. MALLEK

LEO & ANN H. MALLEK

LEO & ANN H. MALLEK


MIDDLE STREET (EXISTING WATER) (PUBLIC)

PLOT PLAN
AMHERST, MASSACHUSETTS
PREPARED FOR

WALTER & DEBBIE KOPEC
APRIL 19, 1979
SCALE: 1"=50'



Harold L. Eaton
HAROLD L. EATON, REGISTERED LAND SURVEYOR
SUNRISE DRIVE - HADLEY - MASSACHUSETTS



DEEP SOIL LOGS

OWNER Leo Mallet



DATE Apr. 31 1978

LOCATION Middle St.

OBSERVER F.A. Filios

Prime Test Pit

Lot #3





GROUND WATER none

GROUND WATER

Alt pit


Rate: 2 minutes per inch



Groundwater none

GROUND WATER





BOARD OF HEALTH

TOWN OF AMHERST, MASSACHUSETTS

LOT #3 MIDDLE ST.

Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner WALTER KOPEC. Address _____


Installer RIVER DRIVE EXC. Address RIVER DRIVE MADLEY

Date Installation Inspected and Approved SEPT. 25, 1979

Description of System: Tank Capacity: 1500


Leach Field () Bed () Seepage Pit (X) Square Feet: 340

Garbage Grinder Yes (X) No () No. Bedrooms: 4 No. People 8



PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.



BOARD OF HEALTH
TOWN OF AMHERST, MASSACHUSETTS

Important Information Regarding Your Private Sewage Disposal System

LOT #3 MIDDLE ST
DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner RESS BLOC LTD Address RTE 66 WEST AMHERST

Installer KARLS INC. Address RIVER DR. AMHERST


Date Installation Inspected and Approved MAY 1983

Description of System: Tank Capacity: 1000

Leach Field () Bed (X) Seepage Pit () Square Feet: 770

Garbage Grinder Yes () No (X) No. Bedrooms: 3 No. People 6

AS - BUILT PLAN:



MIDDLE ST

PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.

