

81-14

#493

BOARD OF HEALTH  
TOWN OF AMHERST, MASSACHUSETTS


Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner DAVID HASTINGS <sup>MONTAGUE ROAD</sup> Address MONTAGUE RD  
Installer W.W. CLARK Address PRATT COENR RD. SWITZERBORO  
Date Installation Inspected and Approved 6-8-82 - (CD)  
Description of System: Tank Capacity: 1000


Leach Field ( ) Bed ( ) Seepage Pit (X) Square Feet: \_\_\_\_\_  
Garbage Grinder Yes ( ) No (X) No. Bedrooms: 3 No. People 6

AS - BUILT PLAN:



PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.



**BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT**

No. 81-14 Date Sept. 24/1981 Fee \$90 Date Rec'd. 9-25-81 By Frederick Filios

Application is hereby made for a permit to construct (X) or Repair ( ) an Individual Sewage Disposal System at:  
 Location—Address Montague Rd. Rt 63 or Lot No. \_\_\_\_\_  
 Owner David Hastings Address 32 N. Prospect St. Amh.  
 Contractor DAVID S. HASTINGS Address 32 N. PROSPECT ST  
 Type of Building WOOD FRAME Dimensions 24 X 32 ft Size Lot 48,000 Sq. Ft. 10 ACRES  
 Dwelling—No. of Bedrooms 3 Expansion Attic ( ) Garbage Grinder ( )  
 Other \_\_\_\_\_ No. of persons \_\_\_\_\_ Showers ( )  
 Other fixtures \_\_\_\_\_  
 Town Water? Yes NO Type of Well drilled 225 ft  
 Design Flow 55 gallons per person per day. Total daily flow 330 gallons  
 Septic Tank—Liquid capacity 1000 gallons Dimensions: L \_\_\_\_\_ W \_\_\_\_\_ D \_\_\_\_\_ 68 Sides 240 gal.  
 Disposal Trench—No. \_\_\_\_\_ Width \_\_\_\_\_ Total Length \_\_\_\_\_ Total leaching area 70 Bottom sq. ft.  
 Disposal Bed—No. \_\_\_\_\_ Diameter \_\_\_\_\_ Depth below inlet \_\_\_\_\_ Total leaching area \_\_\_\_\_ sq. ft.  
 Dry Well—No. 1 Diameter 10 X 7 Depth below inlet 2' Dimensions: 10' x 7' x 2' deep  
 Other: Distribution box ( ) No. \_\_\_\_\_ Dosing tank ( ) Reduced up to 40% with Humus Toilet use  
 (Depth of Soil Line Below finished grade at foundation \_\_\_\_\_)  
 Percolation Test Results Performed by Frederick Filios Date Dec. 9, 1980  
 Test Pit No. 1 2 minutes per inch Depth of Test Pit 8"  
 Test Pit No. 2 \_\_\_\_\_ minutes per inch Depth of Test Pit \_\_\_\_\_  
 Description of Soil provided Depth to Ground Water none  
 Will disposal area be filled? \_\_\_\_\_ Cut down? \_\_\_\_\_  
 (On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by [Signature] David J. Hastings Owner or builder 9/24/81 date  
9/25/81 date

Application Disapproved for the following reasons:

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
CERTIFICATE OF COMPLIANCE**

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed ( ) or repaired ( ) by \_\_\_\_\_ at \_\_\_\_\_ has been constructed in accordance with the provisions of \_\_\_\_\_ INSTALLER Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_  
 The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.  
 DATE \_\_\_\_\_ Inspector \_\_\_\_\_

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS  
DISPOSAL WORKS CONSTRUCTION PERMIT**

No. 81-14  
 Permission is hereby granted DAVID HASTINGS to construct (X) or repair ( ) an Individual Sewage Disposal System at ROUTE 63 - MONTAGUE ROAD as shown on the application for Disposal Works Construction Permit No. 81-14  
 This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.  
 DATE 9-25-81 [Signature] Board of Health

100-15541-100

U.S. DEPARTMENT OF JUSTICE  
FEDERAL BUREAU OF INVESTIGATION

MEMORANDUM FOR THE DIRECTOR

DATE: 10/15/54  
SUBJECT: [Illegible]

[The following text is extremely faint and largely illegible due to the quality of the scan. It appears to be a memorandum detailing an investigation or report.]

Very truly yours,  
[Illegible Signature]

[The following text is extremely faint and largely illegible. It appears to be the body of the memorandum, possibly containing a list of items or a detailed report.]


[Illegible Signature]

# PROFILE OF SEPTIC SYSTEM

For: David Hastings  
32 N. Prospect St  
Amherst Mass.

Scale: Horizontal, 1" = 10'  
Vertical, 1" = 3'

By: Frederick Filios






# PLAN SHOWING SEWAGE DISPOSAL

For: David Hastings  
32 N. Prospect St  
Amherst Mass

Scale: 1" = 40'

By: Frederick Filios



MONTAGUE RD. RT. 63

100  
100




# PERCOLATION TEST LOCATION

For: David Hastings  
32 North Prospect  
Amherst Mass


Scale: 1" = 40'

By: Frederick Filios

Dec. 9 1980



MONTAGUE ROAD ROUTE 63




# DEEP SOIL LOGS

OWNER David Hastings


Date Dec. 9 1980

LOCATION Montague Rd Rt. 63


OBSERVER EA. Filios



Ground Water none



Ground Water \_\_\_\_\_




Ground Water \_\_\_\_\_



Ground Water \_\_\_\_\_

Percolation Rate at 33"

2 minutes/inch







# DEEP SOIL LOGS

OWNER Chester Carl Matusko Jr.

Date Apr. 27 1979


LOCATION Montague Rd Rt. 63

OBSERVER FA Filios



Rate of Percolation @ 42"  
2 minutes/inch






# PERCOLATION TEST LOCATION


For: Chester Carl Matusko Jr.  
113 Middle St.  
Hadley Mass.

Scale: 1" = 40'

By: Frederick Filios



MONTAGUE RD. ROUTE 63







# DEEP SOIL LOGS

OWNER Chester Carl Matusko Jr.

Date Apr. 27 1979

LOCATION Montague Rd Rt. 63

OBSERVER FA Filios



Rate of Percolation @ 42"  
2 minutes/inch



