

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

#340


No. 774-2 Date 7/26/74 Fee \$3.00 Date Rec'd. 7/26/74 By DGF

Application is hereby made for a permit to Construct (✓) or Repair () an Individual Sewage Disposal System at:

Location—Address NORTH EAST ST. or Lot No. MITCHEL FARM
 Owner GENE WAGNER Address NORTH EAST ST. AMHERST
 Contractor Sanders & Roberge Address Bay Rd.
 Type of Building Dwelling Dimensions 24 x 38 Size Lot 150 x 171'
 Dwelling—No. of Bedrooms 3 Expansion Attic (NO) Garbage Grinder (✓)
 Other _____ No. of persons _____ Showers ()
 Other fixtures _____
 Town Water? YES Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 300 gallons
 Septic Tank—Liquid capacity 1000 gallons Dimensions: L 8'-6" W 5'-4" D 4'-10"
 Disposal Trench—No. 1 Width 21 Total Length 30 Total leaching area 600 sq. ft.
 Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.
 Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box () No. _____ Dosing tank ()
 Depth of Soil Line Below finished grade at foundation _____
 Percolation Test Results Performed by LHART - HUNTLEY ASSOCIATES Date _____
 Test Pit No. 1 35+ minutes per inch REAR Depth of Test Pit 2'-10"
 Test Pit No. 2 6 minutes per inch FRONT Depth of Test Pit 3'-3"
 Description of Soil SILT, GRAVEL & SAND Depth to Ground Water 9'
 Will disposal area be filled? _____ Cut down? _____



(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by [Signature] Gene Wagner Owner or builder 7-26-74 date
8-20-74 date

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.
 DATE _____ Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 774-2 Permission is hereby granted GENE WAGNER to construct (X) or repair () an Individual Sewage Disposal System at NORTH EAST ST as shown on the application for Disposal Works Construction Permit No. 774-2

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 8-20-74 [Signature] Board of Health

OPC #

1000
1000
1000


UNITED STATES DEPARTMENT OF JUSTICE
FEDERAL BUREAU OF INVESTIGATION

(10/25)

10/25

LEACH FIELD - 20' FROM HOUSE MIN.
 - 10' FROM P. MIN.
 SEPTIC TANK - 10' FROM
 HOUSE MIN.

LAND OF
 KAZIMER MITCHELL



PLAN OF SEWAGE DISPOSAL SYSTEM ON
 A LOT IN AMHERST, MASSACHUSETTS
 PREPARED FOR
 PATRICIA WAGNER

Almer M. Huntley Jr.



ALMER HUNTLEY, JR. & ASSOCIATES, INC.
 REGISTERED LAND SURVEYORS & CIVIL ENGINEERS
 125 PLEASANT STREET
 NORTHAMPTON, MASS.

DRAWN: S.C.W. SCALE: 1" = 50'
 DATE: 13 AUG 74

NOTE:
 ALL WORK
 TO BE DONE IN
 ACCORDANCE WITH
 STATE SANITARY
 CODE ART. XI

