

#415?

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 46-63 Date Oct 4, Fee 3.00 Date Rec'd. 10/4/63 By FAS.

Application is hereby made for a permit to Construct (X) or Repair () an Individual Sewage Disposal System at:

Location—Address Shays St or Lot No. _____

Owner Miss Florence D. Dwight Address Maltham mass

Contractor George Bugala Address Bay Rd. Amherst.

Type of Building House Dimensions see sketch Size Lot see sketch

Dwelling—No. of Bedrooms 3 Expansion Attic No Garbage Grinder No

Other _____ No. of persons 4 Showers () _____

Other fixtures One Bath + One Kitchen

Town Water? yes Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 300 gallons

Septic Tank—Liquid capacity 900 gallons Dimensions: L _____ W _____ D _____

Disposal Trench—No. _____ Width _____ Total Length _____ Total leaching area _____ sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. One Diameter 8 Depth below inlet 8' Dimensions: 8 x 8 x 10

Other: Distribution box () No. _____ Dosing tank () _____

(Depth of Soil Line Below finished grade at foundation as necessary)

Percolation Test Results Performed by F. A. SIND + G. Bugala Date 10/8/63

Test Pit No. 1 1.5 minutes per inch Depth of Test Pit 30"

Test Pit No. 2 1.4 minutes per inch Depth of Test Pit 30"

Description of Soil gravel Depth to Ground Water 10'+

Will disposal area be filled? a little Cut down? _____

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by F. A. SIND George Bugala 10/4/63
Owner or builder date
10/8/63
date

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed (X) or repaired () by K. KONIENCZY at Shays St. has been constructed in accordance with the provisions of

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. 46-63 dated 10-4-63

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.
DATE 4-9-64 Inspector C. E. Drake

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 46-63
Permission is hereby granted G. Bugala to construct (X) or repair () an Individual Sewage Disposal System at Shays St as shown on the application for Disposal Works Construction Permit No. 46-63

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 10/8/63 F. A. SIND
Board of Health

