

No. 79-16

#56

FEE \$15.00

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Town OF Amherst, Mass.

Application for Disposal Works Construction Permit

Application is hereby made for a Permit to Construct (X) or Repair () an Individual Sewage Disposal System at:


Sherman Lane Lot # 9
Plantation Valley Homes, Inc. 123 Meadow St., Florence, Mass.

Type of Building Dwelling - No. of Bedrooms 3 Expansion Attic () Garbage Grinder (Yes)
Other - Type of Building Frame No. of persons Max. 6 Showers () - Cafeteria ()

Design Flow 55 gallons per person per day. Total daily flow 330 gallons.
Septic Tank - Liquid capacity 1500 gallons Length 10' Width 10' Diameter 30' Depth 5'
Disposal Trench - No. Bed Width 20' Total Length 800 sq. ft. Total leaching area 800 sq. ft.

Percolation Test Results Performed by John A. Brickett Date 10/16/79
Test Pit No. 1 3 minutes per inch Depth of Test Pit 30" Depth to ground water None
Test Pit No. 2 7 minutes per inch Depth of Test Pit 70" Depth to ground water None

Description of Soil 0" to 8" loam - 8" to 24" sandy gravel - no water at 72" to 72" silty



CHECK OR FILL IN WHERE APPLICABLE

Nature of Repairs or Alterations - Answer when applicable

Agreement: The undersigned agrees to install the aforescribed Individual Sewage Disposal System in accordance with the provisions of TITLE 5 of the State Sanitary Code - The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by the board of health.

Signed by Plantation Valley Homes Inc. Date 10/16/79

Application Approved By

Application Disapproved for the following reasons:

Permit No. Issued Date

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Certificate of Compliance

THIS IS TO CERTIFY, That the Individual Sewage Disposal System constructed () or Repaired () by

at has been installed in accordance with the provisions of TITLE 5 of The State Sanitary Code as described in the application for Disposal Works Construction Permit No. dated

THE ISSUANCE OF THIS CERTIFICATE SHALL NOT BE CONSTRUED AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORY.

DATE Inspector

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

No. 79-16 Town OF Amherst FEE \$15.00

Disposal Works Construction Permit

Permission is hereby granted Plantation Valley Homes (LA Valley & Sons) to Construct (X) or Repair () an Individual Sewage Disposal System

at No. Lot # 9 Sherman Lane Street 79-16 Dated 10-23-79


DATE 10-23-79 Board of Health



JOHN A. BRACKETT, R.S.
 19 SUMMER STREET
 GREENFIELD, MASS. 01301
John A. Brackett R.S.
 10/16/79

No Scale


NORTH



DEEP TEST LOG

| | |
|--------------|-----|
| LOAM | 8" |
| | 24" |
| Silty GRAVEL | |
| | 72" |

137.6'



LOT #9
 35,500'²


No water


Town water

100'

116.92'

SHERMAN LANE





LEACHING FIELDS

No Scale

Illustration C

4

1

BOARD OF HEALTH

TOWN OF AMHERST, MASSACHUSETTS

LOT #9 SHEERMAN LANE

Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner PLANTATION VALLEY HOMES Address COTTAGE ST FROEDUCE MA.


Installer JO SPOFF Address MONTAGUE, MA

Date Installation Inspected and Approved 11-13-79

Description of System: Tank Capacity: 1500

Leach Field () Bed (X) Seepage Pit () Square Feet: 800

Garbage Grinder Yes (X) No () No. Bedrooms: 3 No. People 6



PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed _____ years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health.
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.

