

#7

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 774-9 Date Sept 6, 1974 Fee 3.00 Date Rec'd. 9/6/74 By OCB

Application is hereby made for a permit to Construct () or Repair () an Individual Sewage Disposal System at:

Location—Address Sherry Circle or Lot No. 15 *South Orchard Acres*

Owner Everett Roberts Address Pelham Ma

Contractor Roberts Builders Address Amherst Ma

Type of Building 1 Fam App Dimensions 29x62 Size Lot 30,486 ft

Dwelling—No. of Bedrooms 2 Expansion Attic () Garbage Grinder (X)

Other _____ No. of persons 4 Showers ()

Other fixtures _____ Town Water? Yes Type of Well _____

Design Flow 30 gallons per person per day. Total daily flow 250 gallons

Septic Tank—Liquid capacity 1,000 gallons Dimensions: L 35 W _____ D _____

Disposal Trench—No. 1 Width 10 Total Length 35 Total leaching area 350 sq. ft. GD

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box (X) No. _____ Dosing tank ()

(Depth of Soil Line Below finished grade at foundation _____)

Percolation Test Results Performed by Randall G. Pined Date 5/23/73

Test Pit No. 1 3 minutes per inch Depth of Test Pit 3.5'

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil Sandy gravel Depth to Ground Water > 9.0'

Will disposal area be filled? No Cut down? No

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

[Signature] Owner or builder

Sept 6, 1974 date
Sept 6, 1974 date

Application Approved by [Signature]

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE _____

Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 774-9 Permission is hereby granted Roberts Builders to construct (X) or repair () an


Individual Sewage Disposal System at LOT #15 SHERRY CIR

as shown on the application for Disposal Works Construction Permit No. 774-9

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 9-6-74


[Signature]
Board of Health



50' 6 1/2"

"THE CHAMPION LINE" NO. 810

CROSS SECTION - 10 SQUARES TO INCH



PERCOLATION RATE

3 MINUTES PER INCH
MEASURED 5/23/73

LOG OF TEST PIT

TOPSOIL	0.5
SUBSOIL	2.0
SAND SP	5.0
GRAVEL SP-GW	9.0

NO GROUND WATER

DUG 5/10/73

LOT 15
50. ORCHARD ACRES

K.G. LUND
GEOLOGIST

1000



1000



1000

1000