

#4 Stagecoach

Permit # 77-5

BOARD OF HEALTH
TOWN OF AMHERST, MASSACHUSETTS


He will call you.

Important Information Regarding Your Private Sewage Disposal System

DISPLAY THIS DOCUMENT IN A PROMINENT PLACE

Owner HARVEY MESSECK Address MAIN ST. GOSHEN, MA
Installer KARL'S EXCAVATION Address River Dr. Northampton
Date Installation Inspected and Approved 6/19/78
Description of System: Tank Capacity: 1500
Leach Field () Bed (X) Seepage Pit () Square Feet: 1005
Garbage Grinder Yes (X) No () No. Bedrooms: 3 No. People 6

AS - BUILT PLAN:



Mr. Pinsky -
what is procedure
to move septic
tank as
noted
as we want to build
an addition
where it
now is?

STAGECOACH RD.
PROPER MAINTENANCE OF YOUR PRIVATE SEWAGE DISPOSAL SYSTEM

1. This system must be inspected periodically and the tank pumped out at an interval not to exceed 2-3 years.
2. For your protection sanitary pumpers are licensed by the Amherst Board of Health. *Tom Snowman - Ficker*
3. Regular pumping is crucial to avoid early failure and costly repairs of the system.
4. DO NOT dispose into the system such items as rags, string, sanitary napkins, coffee grounds as they can cause it to clog and fail.
5. Further information can be obtained by contacting your Health Department at 253-7077.

(over)

256 1005

(Last pumped '85)

called: 11/4 AT 7:45 - NOT home
11/4 " 9:15 " "

Nov 14, 1988

Talked to MR Miner —
Must move TANK

OR

Replace with new one (TANK)
I need to see installation
before it is covered

DAVE

12/12/88 Have decided not to go forward
on this until next spring.