

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. B-11 Date 3-27-73 Fee 3.00 Date Rec'd. 3-27-73 By CEB

Application is hereby made for a permit to Construct (X) or Repair () an Individual Sewage Disposal System at:

Location—Address STABECOACH RD ELF HILL or Lot No. 212

Owner STEPHEN STANITIS Address W. SPRINGFIELD

Contractor KARLS EXC. Address RIVER DA. N. HADLEY

Type of Building SING RES Dimensions _____ Size Lot .71 ACRES

Dwelling—No. of Bedrooms 4 Expansion Attic (N) Garbage Grinder (Y)

Other _____ No. of persons 8 Showers ()

Other fixtures _____

Town Water? YES Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 500 gallons

Septic Tank—Liquid capacity 1200 gallons Dimensions: L 8 W 4 D 5

Disposal Trench—No. 1 Width 10 Total Length 50 Total leaching area 500 sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box () No. _____ Dosing tank ()

(Depth of Soil Line Below finished grade at foundation _____)

Percolation Test Results Performed by KENDALL G. LUND Date MAR 26 '73

Test Pit No. 1 4 minutes per inch Depth of Test Pit 42"

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil GP-GW sandy gravel Depth to Ground Water 28'

Will disposal area be filled? No Cut down? No

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by [Signature] x [Signature] Owner or builder 3-27-73 date

Application Disapproved for the following reasons: SYSTEM to be located in front SKETCH TO FOLLOW YARD 3-27-73 date

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE _____ Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 73-11 Permission is hereby granted KARLS EXC. S. STANITIS to construct (X) or repair () an Individual Sewage Disposal System at LOT #212 STABECOACH RD

as shown on the application for Disposal Works Construction Permit No. 73-11

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 3-27-73 [Signature] Board of Health

