

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 72-23 Date 8/28/72 Fee 3 Date Rec'd. 9/5/72 By DGF

Application is hereby made for a permit to Construct () or Repair () an Individual Sewage Disposal System at:
 Location—Address Stagecoach Rd Tom McHugh or Lot No. 221
 Owner Ed. Market Address Bay Rd.
 Contractor N. Lawrence Miller Address 3 Laurel Lane
 Type of Building Res. Dimensions 24x56 Size Lot 1 acre
 Dwelling—No. of Bedrooms 4 Expansion Attic () Garbage Grinder ()
 Other 2 1/2 baths No. of persons _____ Showers ()
 Other fixtures _____
 Town Water? yes Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 500 gallons
 Septic Tank—Liquid capacity 1200 gallons Dimensions: L _____ W _____ D _____
 Disposal Trench—No. 2 Width 3 Total Length 130' Total leaching area 400 sq. ft.
 Disposal Bed—No. 1 Diameter 7x11 Depth below inlet 8 Total leaching area 365 sq. ft.
 Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____
 Other: Distribution box () No. _____ Dosing tank () _____

(Depth of Soil Line Below finished grade at foundation _____)
 Percolation Test Results Performed by Kendall G. Lund Date Aug 19, 72
 Test Pit No. 1 4:00 minutes per inch Depth of Test Pit 42"
 Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____
 Description of Soil Silty gravelly sand Depth to Ground Water +12'
 Will disposal area be filled? no Cut down? no
 (On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by C.E. Drake N. Lawrence Miller 8/28/72
 Owner or builder 9-5-72
 date _____
 date _____

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of _____ INSTALLER Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____ The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.
 DATE _____ Inspector _____

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 72-23
 Permission is hereby granted N. Lawrence Miller to construct () or repair () an Individual Sewage Disposal System at 221 - STAGECOACH RD as shown on the application for Disposal Works Construction Permit No. 72-23
 This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.
 DATE 9-5-72 C.E. Drake
 Board of Health

400
Sq. FT
max
CEH

