

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT**

No. 72-25 Date 8/28/72 Fee 43 Date Rec'd. 9/5/72 By DGP

Application is hereby made for a permit to Construct () or Repair () an Individual Sewage Disposal System at:

Location—Address Lot 23 (17) Stage Coach Rd or Lot No. 234

Owner N. Lawrence Miller Address 3 Laurel Lane

Contractor 11 11 Address Amherst

Type of Building Res. Dimensions 28x48 Size Lot 1.04 AC.

Dwelling—No. of Bedrooms 3 Expansion Attic () Garbage Grinder ()

Other 2 possible in basement No. of persons _____ Showers ()

Other fixtures if finished off House to have 1 1/2 baths

Town Water? yes Type of Well _____

Also possible 1/2 bath in basement

Design Flow 50 gallons per person per day. Total daily flow 375 gallons

Septic Tank—Liquid capacity 1000 gallons Dimensions: L _____ W _____ D _____

Disposal Trench—No. 1 Width 10 Total Length 38 Total leaching area 380 sq. ft. *Mrd.*

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____ *CEP*

Other: Distribution box () No. _____ Dosing tank ()

(Depth of Soil Line Below finished grade at foundation)

Percolation Test Results Performed by Randall G. Lund Date Aug. 19, '72

Test Pit No. 1 3 minutes per inch Depth of Test Pit 42"

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil Silty gravelly sand Depth to Ground Water 5.5 feet

Will disposal area be filled? _____ Cut down? _____

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by [Signature] N. Lawrence Miller 8/28/72
Owner or builder date
9-5-72
date

Application Disapproved for the following reasons:
Denwater to 5.5 feet

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE**

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by _____ at _____ has been constructed in accordance with the provisions of

INSTALLER
Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. _____ dated _____

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE _____ Inspector _____

**BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT**

No. 72-25
Permission is hereby granted N. Lawrence Miller to construct () or repair () an Individual Sewage Disposal System at Lot # 234 Stage Coach Rd
as shown on the application for Disposal Works Construction Permit No. 72-25

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 9-5-72 [Signature]
Board of Health

See 72-24.