

Stagecoach Road - Completed

#11

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 72-14 Date 4/25/72 Fee 3.00 Date Rec'd. 5-15-72 By CEH

Application is hereby made for a permit to Construct (X) or Repair () an Individual Sewage Disposal System at:

Location—Address Stagecoach Rd. or Lot No. 235

Owner N. Lawrence Miller Address #2 222 N. East St.

Contractor same Address Amherst, Mass.

Type of Building Ranch Dimensions 32 x 56' 6" Size Lot 1.07 A.

Dwelling—No. of Bedrooms 4 Expansion Attic () Garbage Grinder (X)

Other _____ No. of persons _____ Showers 2 1/2 Baths

Other fixtures _____

Town Water? yes Type of Well _____

Design Flow 50 gallons per person per day. Total daily flow 500 gallons

Septic Tank—Liquid capacity _____ gallons Dimensions: L _____ W _____ D _____

Disposal Trench—No. 1 Width 10 Total Length 50 Total leaching area 500 sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box () No. _____ Dosing tank ()

(Depth of Soil Line Below finished grade at foundation _____)

Percolation Test Results Performed by R.G. Lund Date May 15 72

Test Pit No. 1 10 minutes per inch Depth of Test Pit _____

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil _____ Depth to Ground Water Variable - near surface

Will disposal area be filled? no Cut down? No - contain drain

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

Application Approved by CEH N. Lawrence Miller Owner or builder 5/4 date

Application Disapproved for the following reasons: _____ date 5-15-72

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed (X) or repaired () by KARLS INC. at LOT 235 ELF HILL has been constructed in accordance with the provisions of

INSTALLER Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. 72-14 dated 4-25-72

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE MAR 23, 1973 Inspector CEH


BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 72-14 Permission is hereby granted N. Lawrence Miller to construct (X) or repair () an Individual Sewage Disposal System at LOT 235 STAGECOACH RD


as shown on the application for Disposal Works Construction Permit No. 72-14

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 5-15-72 See plan reverse. Board of Health CEH



Stuyvesant Rd.



Stagecoach Rd.

Curtain drain to be installed at least 6.0' below natural ground or 4.0' below top of ground at base of disposal bed.

K.G.L.

