

426

HOWARD ENVIRONMENTAL SERVICES



TITLE 5 SPECIALISTS

750 NORTH PLEASANT STREET, REAR
AMHERST, MA 01002
PHONE: (413) 256-8008 FAX: (413) 549-1850

David Zarozinski
Inspection Services
Boltwood Walk
Amherst, MA 01002

June 30, 1997

Dear David,

After completing a Title 5 inspection at 426 State Street for Francis Bailey it is our belief that the existing septic system will accommodate an increase in daily flow that will be associated with an expansion from two to three bedrooms. The system was over designed for the time period in which it was installed and because of this it appears to be holding up very well over time.

All the components appear to be in good shape and the three existing leaching trenches provide a combined leaching area of approximately 700 square feet. At todays loading rates for a Class I soil (Loamy Sand), such as those found on the site, the system should be able to accommodate 518 gallons per day of flow.

If you have any questions after reviewing the accompanying report feel free to contact me.

Sincerely,

Mark Thompson

RECEIVED JUL 01 1997

