

525 ~~BAF~~ STATION RD



PERMITS/INSP PAYMENT RECPT#: 11109572
TOWN OF AMHERST
TOWN HALL
4 BOLTWOOD AVENUE
AMHERST MA 01002

DATE: 05/12/11 TIME: 12:50
CLERK: mirj DEPT:

PAID BY: AYOTTE, ROSALIND JON
PAYMENT METH: CHECK 2084

REFERENCE: 9106


AMT TENDERED: 200.00
AMT APPLIED: 200.00
CHANGE: .00

SITE ADDRESS: 525 Station Road

FEES:
HEA058 200.00

TOTAL PAID: 200.00

TITLE 5
INSPECTION
525 Station Rd.
PASSED
APP 9106 115204





**COLD SPRING ENVIRONMENTAL
CONSULTANTS INC.**

received
10-24-07
#1024 \$300

- 2IE Site Investigations
- Subsurface Investigations
- Pollution Remediation
- LSP on Staff
- Forensic Septic Investigations

September 5, 2007

REF 2934

- Percolation Tests
- Septic Designs
- Regulatory Compliance
- Recycling and Solid Waste
- Second Opinions

AMHERST Bd. of Health

RE:Septic System Inspection
525 Station Road

On this date, we inspected the installation of a Soil Absorption System (S. tank and L. Field) found the installation to be complete (except for completion of cover material and final fill) and in compliance with our plans and 310 CMR 15.000.

The installer representative from **(Karls Excavating)** and our inspection noted that the system was built properly, in accordance with the state regulations and our plans. The contractor was requested to have sufficient breakout soil on site and properly cover the system according to our plans and may backfill the system after review by local Health Department representatives.

Sincerely,

Cold Spring Environmental Consultants, Inc.

Alan E. Weiss, M.S., L.S.P.
President
Principal Hydrogeologist
Licensed Site Professional #6442
Registered Sanitarian #933

Cold Spring Environmental
350 Old Enfield Road
Belchertown, Ma. 01007

413-323-5957, phone
413-323-4916, fax

AS BUILT ATTACHED:


1911

11


1911


11

9/5/07



AS BUILT





SUB-GRADE INSPECTION

Location: 525 Station

Property Owner: Ayotte


I certify that I have inspected the excavation to sub-grade of the proposed septic system leaching area prior placement of any fill of stone, or construction of any portion of the system.

I further certify that:

1. All 'A' and 'B' horizon soils (topsoils and subsoils) were removed in the area of the system.
2. There was no evidence of ground water in the excavation.
3. There was no evidence of "mottles" that would be in conflict with the findings of the deep hole soil profile.
4. That the excavation was accomplished to the proper depth and in conformance with the approved plans.

ALAN WEISS
Designers Name

[Signature]
Designers Signature



COLD SPRING ENVIRONMENTAL, INC.
Street Address 850 OLD ENFIELD RD.
BELCHERTOWN, MA 01007

Town, State, Zip Code

413-323-5957
Telephone Number



