

#47

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 29-63 Date 5/8/63 Fee 3.00 Date Rec'd. 5/10/63 By FAS

Application is hereby made for a permit to Construct () or Repair () an Individual Sewage Disposal System at: Valley View Circle or Lot No. 26
Location—Address Keddy Builders Inc. Address 200 N. Main St. E. Long.
Owner DSame Address Same
Contractor Same Address Same
Type of Building Residence Dimensions 26'x38'x33' Size Lot 23,668 sq ft
Dwelling—No. of Bedrooms 3 Expansion Attic () Garbage Grinder ()
Other spec No. of persons spec Showers ()
Other fixtures complete bath, kitchen and laundry
Town Water? yes Type of Well none
Design Flow 50 gallons per person per day. Total daily flow 600 gallons
Septic Tank—Liquid capacity 900 gallons Dimensions: L 10'-3" W 4" D 4"
Disposal Trench—No. 3 Width 36" Total Length 200 Total leaching area 600 sq. ft.
Disposal Bed—No. Diameter Depth below inlet Total leaching area sq. ft.
Dry Well—No. Diameter Depth below inlet Dimensions: x x
Other: Distribution box () No. 1 Dosing tank () 12" or less
(Depth of Soil Line Below finished grade at foundation)
Percolation Test Results Performed by Smith and Wallen Engineering Date
Test Pit No. 1 20 minutes per inch Depth of Test Pit 3 feet
Test Pit No. 2 minutes per inch Depth of Test Pit
Description of Soil Sand and gravel Depth to Ground Water see affidavit
Will disposal area be filled? Cut down?
(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

[Signature] 5/8/63
Owner or builder date
F.A. Siino 5/8/63
Application Approved by date

Application Disapproved for the following reasons:

copy to bank


BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by Keddy Builders Inc. at Lot No. 26 has been constructed in accordance with the provisions of Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. 29-63 dated 5/8/63.
The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.
DATE 7/19/63 Inspector [Signature]

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 29-63
Permission is hereby granted Keddy Builders Inc. to construct () or repair () an Individual Sewage Disposal System at Lot 26 - Valley View Circle as shown on the application for Disposal Works Construction Permit No. 29-63
This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 5/8/63 F.A. Siino
Board of Health [Signature]



$$\begin{array}{r} 2 \\ 57 \\ 3 \\ \hline 171 \\ 38 \\ \hline 209 - 3' \text{ width} \end{array}$$

