

#56

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
APPLICATION FOR DISPOSAL WORKS CONSTRUCTION PERMIT

No. 16-63 Date 6/8/63 Fee 3.00 Date Rec'd. 5/10/63 By FAS

Application is hereby made for a permit to Construct () or Repair () an Individual Sewage Disposal System at:

Location—Address Valley View Drive or Lot No. 13

Owner Keddy Builders Inc. Address 200 N. Main St. E. Long.

Contractor Same Address Same

Type of Building Residence Dimensions 26'x38'x33' Size Lot 20,000 sq ft

Dwelling—No. of Bedrooms 3 Expansion Attic () Garbage Grinder ()

Other _____ No. of persons spec Showers ()

Other fixtures complete bath and laundry

Town Water? yes Type of Well none

Design Flow 50 gallons per person per day. Total daily flow 600 gallons

Septic Tank—Liquid capacity 900 gallons Dimensions: L 10'-3" W 4' D 4'

Disposal Trench—No. 3 Width 3 Total Length 150' Total leaching area 300 sq. ft.

Disposal Bed—No. _____ Diameter _____ Depth below inlet _____ Total leaching area _____ sq. ft.

Dry Well—No. _____ Diameter _____ Depth below inlet _____ Dimensions: _____ x _____ x _____

Other: Distribution box () No. 1 Dosing tank ()

(Depth of Soil Line Below finished grade at foundation 12" or less)

Percolation Test Results Performed by Smith & Wallen Engineering Co. Date 4/30/63

Test Pit No. 1 10 minutes per inch Depth of Test Pit 3 feet

Test Pit No. 2 _____ minutes per inch Depth of Test Pit _____

Description of Soil Gravel and sandy clay Depth to Ground Water See affidavit

Will disposal area be filled? _____ Cut down? _____

(On reverse side or separate sheet, show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

AGREEMENT: The undersigned agrees to construct the aforedescribed individual sewage disposal system in accordance with the provisions of Article XI of the Sanitary Code and regulations of the Amherst Board of Health. The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by this board of health.

F. A. Siino 5/8/63
 Owner or builder date
5/8/63
 date

Application Approved by F.A. Siino

Application Disapproved for the following reasons:

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY, That the individual Sewage Disposal System installed () or repaired () by Keddy Builders Inc at Lot No. 13 has been constructed in accordance with the provisions of

INSTALLER

Article XI of the State Sanitary Code as described in the application for Disposal Works Construction Permit No. 16-63 dated 5/8/63

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily.

DATE 7/19/63 Inspector *F. A. Siino*

BOARD OF HEALTH, AMHERST, MASSACHUSETTS
DISPOSAL WORKS CONSTRUCTION PERMIT

No. 16-63
 Permission is hereby granted Keddy Builders Inc. to construct () or repair () an Individual Sewage Disposal System at Lot 13 - Valley View Dr.


as shown on the application for Disposal Works Construction Permit No. 16-63
 This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

DATE 5/8/63 F.A. Siino
 Board of Health *F*

FAS

5/10/63

16-63



$$\begin{array}{r} 136 \\ 24 \\ \hline 160 \\ 3 \\ \hline 480 \end{array}$$

5/8/63

F.A. Siano

x

Kedy Builders Inc.
 Lot 13 - Valley View Dr.
 16-63

16-63

F.A. Siano

5/8/63

5/8/63

