

APPLICATION FOR PERMIT TO CONSTRUCT OR REPAIR
A PRIVATE SEWAGE DISPOSAL SYSTEM

TO: THE BOARD OF HEALTH, AMHERST, MASS.

No.

Herbert A. Randolph
(owner's name)

of 47 Pokeberry Ridge
(address)

3-7089
(phone)

hereby applies for a permit to construct or repair a private disposal system for a **residence**.....
(residence, store, etc.)

which will be located at 174 West Street..... to be installed by

Miner Tuttle, Jr.
(name)

So. East Street
(address)

3-5129
(phone)

Builder is Plumber is Valdemar Tidlund.....

Description of lot, building and fixtures as follows:

Lot: Dimensions 6/10 Acre..... Type of Soil..... Well or Town Water? Town Water.....

Distance to Town Sewer Depth to Ground Water Kind of Well

Will Lot be Graded? Yes..... By Filling or Removing Soil? Removing.....

Building: Dimensions 24' x 42'..... No. Bedrooms 2..... No. Occupants 3.....

Fixtures: No. Toilets 1..... Urinals 0..... Wash Basins 1..... Bathtubs 1.....

Showers 0..... Kitchen Sinks 1..... Garbage Grinders 0.....

Auto Dishwasher 0..... Auto. Clotheswasher 1..... Other (basement)

(On reverse side show plot plan with building. Include dimensions, distances from all boundaries. Show location of wells, streams, ledge, large trees, etc.)

I certify that the above information is correct and that I will notify the Board of Health if any conditions are changed. I also declare that I have read and understand all the rules and regulations applying hereto and will comply with all requirements and stipulations as included in a permit if issued to me.

Date 9/28/59.....

Herbert A. Randolph
(Signature of Applicant)

PERMIT TO CONSTRUCT OR REPAIR A PRIVATE SEWAGE DISPOSAL SYSTEM

No.

H. RANDOLPH..... is hereby granted permission to proceed with the construction or repair of private sewage disposal system with the following minimum requirements:

Septic Tank: Must be of Cement and of 600 Gals. Liquid Capacity.

Leaching System: Trenches of not less than 240 Sq. Ft. bottom area. 3-40ft Trench plus
Dry well ft. bottom area and ft. below the inlet. DIST. BOX
Other

This permit is issued with the understanding that future alterations or additions will be made if necessary. This permit shall not be construed as permission to create or maintain any sewage nuisance and in the issuance of this permit the Board of Health assumes no responsibility for the future operation or maintenance of the system.

G. A. Lewis..... 9/28/59
for the Board of Health date

Inspected Approved Approved 11/6/59.....

WEST SY

STAFFS

